



WATER TREATMENT PLANT & DISTRIBUTION SYSTEM



2015 Annual Operations Performance Report

Facility Numbers 529 & 155



TABLE OF CONTENTS

1. OVERVIEW	I
2. PERMIT TO OPERATE	I
3. CERTIFIED OPERATORS	I
4. OPERATIONAL HIGHLIGHTS.....	2
5. RAW AND TREATED WATER PRODUCTION.....	3
6. CHEMICAL USAGE	3
7. FILTERED WATER QUALITY	4
8. RESERVOIR EFFLUENT.....	4
9. DISTRIBUTION WATER QUALITY AND BACTERIOLOGICAL RESULTS.....	5
10. TRIHALOMETHANE/HALOACETIC ACID RESULTS.....	9

DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015



Overview

Port Hardy, with a population of about 5,000 people, is located at the northern end of Vancouver Island. In May 2000 the new water treatment plant was commissioned and helped Port Hardy's reputation of poor water quality to one of the best in British Columbia.

Port Hardy's source water is the Tsulquate River. The water from this river is tinted brown from tannins and other leachates. Port Hardy's Water Treatment Plant uses a Dissolved Air Flotation (DAF) system which is very effective in treating highly colored water. Treatment is achieved using ISOPAC 6 and Soda Ash to remove the color, particles, sediment and organics that are present. A filter aid, Hydrofloc 400 is added in trace amounts after the DAF treatment and prior to the filters to improve coagulation of fine particles. Filtration is done through a mixed media consisting silica sand and anthracite. Lime slurry, carbon dioxide and sodium hypochlorite are injected post filtration for alkalinity, pH adjustment and disinfection.

In 2015, the plant continued to produce a very high level of treatment providing excellent water quality to the District of Port Hardy.

Permit to Operate

The Port Hardy water treatment plant is a Level III facility as deemed by the Environmental Operators Certification Program (EOCP), certification number 529. The distribution system is a Level III system with a certification number of 155.

Certified Operators

The Operational Permit from Vancouver Island Health Authority Operational requires that a certified operator is employed to match the Water Treatment Plant Certification, a level III plant. The District currently employs a Level IV operator and one Level II operator.

Operator	Title	Certification
Joe Jewell	Utilities Supervisor	WT IV, WWT II, WD II, WWC I
Justin Reusch	Chief Operator	WT II, WD I, WWT II
Roland LeFort	Operator	WWT III, WT II
Cory Henschke	Operator	WWT I, WD II

DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015



OPERATIONAL HIGHLIGHTS

Water Treatment Plant

Throughout the course of 2015, there were times where due to heavy rains and high river colour events, that the water treatment process was upset. In these events, the plant is taken offline and no water is pumped to the reservoir. Water is only pumped to the reservoirs once the treatment plant's process quality is restored. This will result in lower than desired reservoir levels but quality will not be compromised.

- There were no violations to permit in 2015
- A forest fire in June came very close to the water treatment plant. This details of this fire are found on the BC Wildfire Service website under "Tsulquate River Wildfire V70290"
- Low river levels triggered a Stage 3 water use restriction as per Port Hardy Water Conservation Bylaw No. 06-2005
- A new processor was installed in the main plant PLC in November as well as a new soda ash flow meter after months of ongoing issues
- Remote access was established to the District SCADA network enabling remote access

Water Distribution System

- A service saddle on the water main on Beaver Harbour Road needed to be repaired
- 2 hydrants serviced and a new hydrant installed in front of the new medical clinic
- In December, the mainline supplying Fisherman's Wharf was repaired after breaking at the pipe joint
- 3 water meters on commercial buildings were replaced in 2015 due to shallow installation causing the meters to freeze and break
- In response to complaints regarding leaks in the private water distribution system at the Highview Mobile Home Park, and the risks presented by this cross connection, the owners installed new water mains and a cross connection control device. This will help to conserve drinking water and protect the District's water distribution system

Cross Connection Control

A formal Cross Connection Control program was presented to the District of Port Hardy in late 2010. This system was created by Maintenance Tracking Systems Inc (MTS). Currently, backflow preventers are installed in all treatment plants in areas that may be a possible risk. In 2008, all sewage liftstations with wash down hose bibs were upgraded with backflow preventers.

Water Wise Program Continuation

A total of 175 meters are being read including commercial users and multi-family dwellings. All new homes and constructions will have meter setters installed as part of this program. Continuing public education around proposed metering/rate changes and general information on water wise initiatives was conducted and will be ongoing until all users are metered.

**DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015**



RAW AND TREATED WATER PRODUCTION

Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
Raw Water Pumped in ML	144	127	141	137	145	162	161	158	143	137	142	148	1745
Treated Water Production in ML	141	124	139	134	142	159	158	152	139	135	139	145	1708
Rainfall in mm	223	99	197.6	120.8	5.2	16	45	92.8	130.4	222.2	121.2	265.4	1534
Backwashes	40	36	36	38	35	35	34	35	39	36	42	48	454

CHEMICAL USAGE

Month	January	February	March	April	May	June	July	August	September	October	November	December	Total
ISOPAC 6 Coagulant in kg	5529	5485	6474	5614	3928	3363	3805	6032	7718	7914	6787	5578	68227
Soda Ash in kg	2835	2659	3192	2884	1829	1399	1688	2708	3445	2934	2602	2436	30612
Filter Aid (LT20) in kg	1.11	0.95	1.07	1.21	0.88	0.63	0.96	0.89	1.06	1.07	1.15	1.36	12.32
Salt for Chlorine Generator in kg	693	596	698	652	627	677	680	772	736	708	534	642	8014
Liquid Sodium Hypochlorite 12% in kg				0	0	0	0	0	0	0	0	0	0
Lime in kg	2946	2362	2852	2683	2576	2369	2229	2223	2226	2107	2106	2298	28978
Carbon Dioxide in kg	3411	2723	3648	2863	3349	2719	2845	3098	2255	2968	2867	2398	35144

**DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015**



FILTERED WATER QUALITY

Month	Filter 1		Filter 2		Filter 3		Filter 4	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max
January	0.03	0.29	0.04	0.27	0.04	0.25	0.03	0.23
February	0.03	0.29	0.04	0.29	0.03	0.29	0.04	0.29
March	0.03	0.25	0.04	0.28	0.03	0.29	0.03	0.26
April	0.03	0.08	0.04	0.12	0.03	0.09	0.04	0.12
May	0.03	0.06	0.03	0.23	0.03	0.08	0.03	0.08
June	0.03	0.08	0.03	0.10	0.04	0.11	0.03	0.09
July	0.04	0.10	0.04	0.10	0.04	0.10	0.03	0.09
August	0.03	0.09	0.04	0.10	0.04	0.10	0.03	0.09
September	0.03	0.09	0.04	0.11	0.04	0.10	0.03	0.09
October	0.03	0.08	0.04	0.11	0.03	0.10	0.03	0.10
November	0.03	0.26	0.04	0.29	0.04	0.29	0.03	0.29
December	0.03	0.28	0.04	0.28	0.04	0.18	0.03	0.26
Average	0.03	0.16	0.04	0.19	0.04	0.16	0.03	0.17
Minimum	0.03	0.06	0.03	0.10	0.03	0.08	0.03	0.08
Maximum	0.04	0.29	0.04	0.29	0.04	0.29	0.04	0.29

RESERVOIR EFFLUENT

Month	Flow (m ³ /hour)		Free Chlorine (mg/L)		pH		Turbidity (NTU)	
	Avg	Max	Avg	Max	Avg	Max	Avg	Max
January	166	234	1.1	1.1	7.2	7.5	0.07	3.62
February	162	239	1.1	1.1	7.4	7.5	0.03	0.29
March	163	237	1.1	1.2	7.2	7.4	0.02	0.13
April	164	244	1.0	1.2	7.2	7.4	0.03	0.29
May	170	242	0.9	0.9	7.2	7.5	0.03	0.29
June	194	292	0.9	0.9	7.3	7.4	0.03	0.29
July	181	263	0.8	0.9	7.4	7.5	0.03	0.29
August	174	287	1.0	1.0	7.3	7.5	0.06	0.17
September	163	273	1.0	1.0	7.1	7.2	0.05	0.29
October	152	254	1.0	1.0	7.4	7.5	0.04	0.16
November	161	267	0.9	1.1	7.2	7.3	0.05	0.29
December	166	260	1.0	1.0	7.2	7.3	0.05	0.14
Avg	168	258	1.0	1.1	7.3	7.4	0.04	0.52
Min	152	234	0.8	0.9	7.1	7.2	0.02	0.13
Max	194	292	1.1	1.2	7.4	7.5	0.07	3.62

DISTRICT OF PORT HARDY

WATER SYSTEM ANNUAL REPORT 2015



DISTRIBUTION WATER QUALITY AND BACTERIOLOGICAL RESULTS

January					February					March																																																																																																																																																																																																																																																																																				
Distribution Sampling					Distribution Sampling					Distribution Sampling																																																																																																																																																																																																																																																																																				
Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH																																																																																																																																																																																																																																																																																
Chatham Avenue	01/07/15	0.5	0.21	8.1	Chatham Avenue	02/03/15	0.6	0.13	7.9	Chatham Avenue	03/03/15	0.6	0.20	7.7																																																																																																																																																																																																																																																																																
	01/12/15	0.6	0.24	8.2		01/13/15	0.6	0.16	7.9		01/20/15	0.8	0.20	8.1	01/26/15	0.7	0.13	8.0	Peel Street Liftstation	01/07/15	0.9	0.23	7.8	Peel Street Liftstation	02/03/15	0.8	0.14	7.5	Peel Street Liftstation	03/03/15	1.0	0.15	7.4	01/13/15	0.8	0.33	7.6	01/20/15	1.0	0.31	7.8	01/26/15	0.9	0.18	7.4	Airport Wastewater Treatment Plant	01/07/15	0.2	0.64	7.5	Airport Wastewater Treatment Plant	02/03/15	0.4	0.36	7.6	Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6	01/13/15	0.2	0.42	7.5	01/20/15	0.5	0.31	7.9	01/26/15	0.2	0.39	7.5	Public Works Yard	01/07/15	0.8	0.39	7.9	Public Works Yard	02/03/15	0.9	0.14	7.7	Public Works Yard	03/03/15	1.0	0.18	7.5	01/13/15	0.9	0.19	7.7	01/20/15	1.1	0.15	7.9	01/26/15	1.1	0.25	7.6	Eagleview School	01/08/15	0.8	0.64	7.4	Eagleview School	02/03/15	0.8	0.13	7.9	Eagleview School	03/03/15	0.9	0.15	7.6	01/14/15	0.4	0.40	7.7	01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir	01/07/15	0.9	0.20	7.8	Bear Cove Reservoir	02/03/15	0.8	0.15	7.5	Bear Cove Reservoir	03/03/15	0.9	0.12	7.51	01/13/15	0.8	0.24	7.6	01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25	7.6	Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7	0.13	7.4	01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5	Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																		
	01/13/15	0.6	0.16	7.9		01/20/15	0.8	0.20	8.1		01/26/15	0.7	0.13	8.0	Peel Street Liftstation	01/07/15	0.9	0.23		7.8	Peel Street Liftstation	02/03/15	0.8		0.14	7.5	Peel Street Liftstation	03/03/15		1.0	0.15	7.4	01/13/15	0.8	0.33	7.6	01/20/15	1.0	0.31	7.8	01/26/15	0.9	0.18	7.4	Airport Wastewater Treatment Plant		01/07/15	0.2	0.64	7.5		Airport Wastewater Treatment Plant	02/03/15	0.4	0.36		7.6	Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6	01/13/15	0.2	0.42	7.5	01/20/15	0.5	0.31	7.9	01/26/15	0.2		0.39	7.5	Public Works Yard	01/07/15		0.8	0.39	7.9	Public Works Yard		02/03/15	0.9	0.14	7.7	Public Works Yard	03/03/15	1.0	0.18	7.5	01/13/15	0.9	0.19	7.7	01/20/15	1.1	0.15		7.9	01/26/15	1.1	0.25		7.6	Eagleview School	01/08/15	0.8		0.64	7.4	Eagleview School	02/03/15	0.8	0.13	7.9	Eagleview School	03/03/15	0.9	0.15	7.6	01/14/15	0.4	0.40	7.7		01/22/15	0.8	0.93	7.8		01/29/15	0.5	0.21	7.7		Bear Cove Reservoir	01/07/15	0.9	0.20	7.8	Bear Cove Reservoir	02/03/15	0.8	0.15	7.5	Bear Cove Reservoir	03/03/15	0.9	0.12	7.51	01/13/15		0.8	0.24	7.6	01/20/15		0.9	0.15	7.6	01/26/15		0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25	7.6	Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7		0.13	7.4	01/12/15	0.7		0.22	7.6	01/20/15	0.8		0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5	Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																	
	01/20/15	0.8	0.20	8.1		01/26/15	0.7	0.13	8.0		Peel Street Liftstation	01/07/15	0.9	0.23		7.8	Peel Street Liftstation	02/03/15		0.8		0.14	7.5		Peel Street Liftstation	03/03/15		1.0		0.15	7.4	01/13/15	0.8	0.33	7.6	01/20/15	1.0	0.31	7.8	01/26/15	0.9	0.18	7.4	Airport Wastewater Treatment Plant			01/07/15	0.2	0.64	7.5			Airport Wastewater Treatment Plant	02/03/15	0.4		0.36		7.6	Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6	01/13/15	0.2	0.42	7.5	01/20/15	0.5	0.31	7.9		01/26/15	0.2		0.39		7.5	Public Works Yard	01/07/15			0.8	0.39	7.9	Public Works Yard		02/03/15	0.9	0.14	7.7	Public Works Yard	03/03/15	1.0	0.18	7.5	01/13/15	0.9		0.19	7.7	01/20/15	1.1		0.15		7.9	01/26/15		1.1	0.25		7.6	Eagleview School	01/08/15	0.8		0.64	7.4	Eagleview School	02/03/15	0.8	0.13	7.9	Eagleview School		03/03/15	0.9	0.15	7.6		01/14/15	0.4	0.40	7.7			01/22/15	0.8	0.93	7.8		01/29/15	0.5	0.21	7.7		Bear Cove Reservoir	01/07/15	0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15		7.5	Bear Cove Reservoir	03/03/15	0.9		0.12	7.51	01/13/15		0.8	0.24	7.6	01/20/15		0.9	0.15	7.6	01/26/15		0.8	0.15		7.5	Ferry Terminal	01/07/15	0.5		0.25	7.6	Ferry Terminal	02/03/15		0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7		0.13	7.4	01/12/15	0.7		0.22	7.6	01/20/15	0.8		0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5	Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1
	01/26/15	0.7	0.13	8.0		Peel Street Liftstation	01/07/15	0.9	0.23			7.8	Peel Street Liftstation	02/03/15		0.8		0.14		7.5		Peel Street Liftstation	03/03/15			1.0		0.15		7.4	01/13/15	0.8	0.33	7.6	01/20/15	1.0	0.31	7.8	01/26/15	0.9	0.18	7.4	Airport Wastewater Treatment Plant				01/07/15	0.2	0.64	7.5				Airport Wastewater Treatment Plant	02/03/15		0.4		0.36		7.6	Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6	01/13/15	0.2	0.42	7.5	01/20/15	0.5		0.31	7.9		01/26/15		0.2		0.39			7.5	Public Works Yard	01/07/15			0.8	0.39	7.9	Public Works Yard		02/03/15	0.9	0.14	7.7	Public Works Yard	03/03/15		1.0	0.18	7.5	01/13/15		0.9		0.19	7.7		01/20/15	1.1		0.15		7.9	01/26/15		1.1	0.25		7.6	Eagleview School	01/08/15	0.8			0.64	7.4	Eagleview School	02/03/15		0.8	0.13	7.9	Eagleview School			03/03/15	0.9	0.15	7.6		01/14/15	0.4	0.40	7.7			01/22/15	0.8	0.93	7.8			01/29/15	0.5	0.21		7.7		Bear Cove Reservoir	01/07/15		0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15		7.5	Bear Cove Reservoir	03/03/15	0.9		0.12	7.51		01/13/15		0.8	0.24		7.6	01/20/15		0.9		0.15	7.6	01/26/15		0.8	0.15		7.5	Ferry Terminal	01/07/15	0.5		0.25	7.6	Ferry Terminal	02/03/15		0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7		0.13	7.4	01/12/15	0.7		0.22	7.6	01/20/15	0.8		0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5	Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3
Peel Street Liftstation	01/07/15	0.9	0.23	7.8	Peel Street Liftstation		02/03/15	0.8	0.14	7.5		Peel Street Liftstation		03/03/15		1.0		0.15	7.4																																																																																																																																																																																																																																																																											
	01/13/15	0.8	0.33	7.6			01/20/15	1.0	0.31	7.8				01/26/15	0.9	0.18		7.4	Airport Wastewater Treatment Plant	01/07/15	0.2		0.64	7.5		Airport Wastewater Treatment Plant	02/03/15	0.4	0.36	7.6	Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6	01/13/15	0.2	0.42	7.5	01/20/15	0.5	0.31			7.9	01/26/15	0.2	0.39	7.5	Public Works Yard	01/07/15	0.8			0.39	7.9	Public Works Yard	02/03/15	0.9		0.14		7.7	Public Works Yard	03/03/15	1.0	0.18	7.5	01/13/15	0.9	0.19	7.7	01/20/15	1.1	0.15	7.9	01/26/15	1.1	0.25		7.6	Eagleview School	01/08/15	0.8		0.64		7.4	Eagleview School	02/03/15	0.8			0.13	7.9	Eagleview School	03/03/15		0.9	0.15	7.6	01/14/15	0.4	0.40	7.7	01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir		01/07/15	0.9	0.20	7.8	Bear Cove Reservoir		02/03/15		0.8	0.15		7.5	Bear Cove Reservoir	03/03/15		0.9	0.12	7.51	01/13/15	0.8		0.24	7.6	01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15		0.5	0.25	7.6	Ferry Terminal	02/03/15		0.8	0.19	7.5	Ferry Terminal	03/03/15			0.7	0.13	7.4	01/12/15	0.7	0.22		7.6	01/20/15	0.8	0.14	7.6		01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0		0.26	7.5	Highway 19 PRV	02/03/15	0.9		0.18	7.6	Highway 19 PRV	03/03/15	1.1		0.17	7.4	01/13/15	1.0		0.21	7.7	01/20/15	1.1	0.34		8.6	01/26/15	1.0	0.13	7.5		Average			0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2		0.13	7.4	Minimum			0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																										
	01/20/15	1.0	0.31	7.8			01/26/15	0.9	0.18	7.4	Airport Wastewater Treatment Plant			01/07/15	0.2	0.64	7.5	Airport Wastewater Treatment Plant		02/03/15	0.4		0.36	7.6	Airport Wastewater Treatment Plant		03/03/15	0.9	0.23	7.6		01/13/15	0.2	0.42	7.5	01/20/15	0.5	0.31	7.9	01/26/15	0.2	0.39		7.5	Public Works Yard	01/07/15	0.8	0.39	7.9		Public Works Yard	02/03/15	0.9		0.14	7.7		Public Works Yard	03/03/15	1.0	0.18		7.5		01/13/15	0.9	0.19	7.7	01/20/15	1.1	0.15	7.9	01/26/15	1.1	0.25	7.6	Eagleview School	01/08/15	0.8	0.64	7.4		Eagleview School	02/03/15		0.8	0.13	7.9		Eagleview School	03/03/15		0.9	0.15	7.6		01/14/15		0.4	0.40	7.7	01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir	01/07/15	0.9	0.20		7.8	Bear Cove Reservoir	02/03/15	0.8	0.15		7.5	Bear Cove Reservoir		03/03/15	0.9	0.12	7.51		01/13/15		0.8	0.24	7.6	01/20/15	0.9		0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25		7.6	Ferry Terminal	02/03/15	0.8	0.19		7.5	Ferry Terminal	03/03/15	0.7	0.13		7.4	01/12/15		0.7	0.22	7.6	01/20/15	0.8	0.14		7.6	01/26/15	0.7	0.13	7.6		Highway 19 PRV	01/07/15	1.0	0.26		7.5	Highway 19 PRV	02/03/15	0.9	0.18		7.6	Highway 19 PRV	03/03/15	1.1	0.17		7.4	01/13/15	1.0	0.21	7.7	01/20/15	1.1		0.34	8.6	01/26/15	1.0	0.13		7.5	Average		0.7	0.28		7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3		0.11	7.4	Minimum			0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																															
	01/26/15	0.9	0.18	7.4		Airport Wastewater Treatment Plant	01/07/15	0.2	0.64	7.5			Airport Wastewater Treatment Plant	02/03/15	0.4	0.36	7.6			Airport Wastewater Treatment Plant	03/03/15	0.9	0.23	7.6			01/13/15	0.2	0.42	7.5		01/20/15	0.5	0.31	7.9	01/26/15	0.2	0.39	7.5	Public Works Yard	01/07/15	0.8	0.39	7.9		Public Works Yard	02/03/15	0.9	0.14			7.7	Public Works Yard	03/03/15	1.0	0.18			7.5	01/13/15	0.9	0.19	7.7		01/20/15	1.1	0.15	7.9	01/26/15	1.1	0.25	7.6	Eagleview School	01/08/15	0.8	0.64		7.4	Eagleview School	02/03/15	0.8			0.13	7.9	Eagleview School	03/03/15	0.9			0.15	7.6	01/14/15	0.4	0.40		7.7	01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir	01/07/15	0.9	0.20		7.8	Bear Cove Reservoir	02/03/15		0.8		0.15	7.5	Bear Cove Reservoir		03/03/15		0.9	0.12	7.51	01/13/15	0.8		0.24	7.6	01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25		7.6	Ferry Terminal	02/03/15		0.8		0.19	7.5	Ferry Terminal		03/03/15		0.7	0.13	7.4		01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26		7.5	Highway 19 PRV	02/03/15		0.9		0.18	7.6	Highway 19 PRV		03/03/15		1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																					
Airport Wastewater Treatment Plant	01/07/15	0.2	0.64	7.5	Airport Wastewater Treatment Plant		02/03/15	0.4	0.36	7.6		Airport Wastewater Treatment Plant		03/03/15	0.9	0.23	7.6																																																																																																																																																																																																																																																																													
	01/13/15	0.2	0.42	7.5			01/20/15	0.5	0.31	7.9				01/26/15	0.2	0.39	7.5		Public Works Yard		01/07/15	0.8	0.39	7.9		Public Works Yard	02/03/15	0.9	0.14	7.7	Public Works Yard	03/03/15	1.0	0.18	7.5	01/13/15	0.9	0.19	7.7		01/20/15	1.1	0.15	7.9			01/26/15	1.1	0.25	7.6		Eagleview School		01/08/15	0.8	0.64	7.4		Eagleview School	02/03/15	0.8	0.13	7.9	Eagleview School	03/03/15	0.9	0.15	7.6	01/14/15	0.4	0.40	7.7		01/22/15	0.8	0.93		7.8		01/29/15	0.5	0.21		7.7	Bear Cove Reservoir		01/07/15	0.9	0.20		7.8	Bear Cove Reservoir	02/03/15	0.8	0.15	7.5	Bear Cove Reservoir	03/03/15	0.9	0.12	7.51	01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15		7.6		01/26/15	0.8	0.15		7.5	Ferry Terminal		01/07/15	0.5		0.25	7.6	Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7	0.13	7.4	01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14		7.6		01/26/15	0.7	0.13		7.6	Highway 19 PRV		01/07/15	1.0		0.26	7.5	Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34		8.6		01/26/15	1.0	0.13		7.5	Average		0.7	0.28		7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																									
	01/20/15	0.5	0.31	7.9			01/26/15	0.2	0.39	7.5	Public Works Yard			01/07/15	0.8	0.39	7.9	Public Works Yard			02/03/15	0.9	0.14	7.7	Public Works Yard		03/03/15	1.0	0.18	7.5		01/13/15	0.9	0.19	7.7	01/20/15	1.1	0.15	7.9		01/26/15	1.1	0.25	7.6	Eagleview School		01/08/15	0.8	0.64	7.4	Eagleview School			02/03/15	0.8	0.13	7.9	Eagleview School		03/03/15	0.9	0.15	7.6		01/14/15	0.4	0.40	7.7	01/22/15	0.8	0.93	7.8		01/29/15	0.5	0.21	7.7	Bear Cove Reservoir		01/07/15	0.9	0.20	7.8	Bear Cove Reservoir			02/03/15	0.8	0.15	7.5	Bear Cove Reservoir		03/03/15	0.9	0.12	7.51		01/13/15	0.8	0.24	7.6	01/20/15	0.9	0.15	7.6		01/26/15	0.8	0.15	7.5	Ferry Terminal		01/07/15	0.5	0.25	7.6	Ferry Terminal			02/03/15	0.8	0.19	7.5	Ferry Terminal		03/03/15	0.7	0.13	7.4		01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6		01/26/15	0.7	0.13	7.6	Highway 19 PRV		01/07/15	1.0	0.26	7.5	Highway 19 PRV			02/03/15	0.9	0.18	7.6	Highway 19 PRV		03/03/15	1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6		01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																
	01/26/15	0.2	0.39	7.5		Public Works Yard	01/07/15	0.8	0.39	7.9			Public Works Yard	02/03/15	0.9	0.14	7.7			Public Works Yard	03/03/15	1.0	0.18	7.5			01/13/15	0.9	0.19	7.7		01/20/15	1.1	0.15	7.9	01/26/15	1.1	0.25	7.6	Eagleview School	01/08/15	0.8	0.64	7.4		Eagleview School	02/03/15	0.8	0.13	7.9			Eagleview School	03/03/15	0.9	0.15	7.6			01/14/15	0.4	0.40	7.7		01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir	01/07/15	0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15	7.5			Bear Cove Reservoir	03/03/15	0.9	0.12	7.51			01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5			Ferry Terminal	03/03/15	0.7	0.13	7.4			01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6			Highway 19 PRV	03/03/15	1.1	0.17	7.4			01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																						
Public Works Yard	01/07/15	0.8	0.39	7.9	Public Works Yard		02/03/15	0.9	0.14	7.7		Public Works Yard		03/03/15	1.0	0.18	7.5																																																																																																																																																																																																																																																																													
	01/13/15	0.9	0.19	7.7			01/20/15	1.1	0.15	7.9				01/26/15	1.1	0.25	7.6		Eagleview School		01/08/15	0.8	0.64	7.4		Eagleview School	02/03/15	0.8	0.13	7.9	Eagleview School	03/03/15	0.9	0.15	7.6	01/14/15	0.4	0.40	7.7		01/22/15	0.8	0.93	7.8			01/29/15	0.5	0.21	7.7		Bear Cove Reservoir		01/07/15	0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15	7.5	Bear Cove Reservoir	03/03/15	0.9	0.12	7.51	01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15	7.6			01/26/15	0.8	0.15	7.5		Ferry Terminal		01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7	0.13	7.4	01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6			01/26/15	0.7	0.13	7.6		Highway 19 PRV		01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6			01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																											
	01/20/15	1.1	0.15	7.9			01/26/15	1.1	0.25	7.6	Eagleview School			01/08/15	0.8	0.64	7.4	Eagleview School			02/03/15	0.8	0.13	7.9	Eagleview School		03/03/15	0.9	0.15	7.6		01/14/15	0.4	0.40	7.7	01/22/15	0.8	0.93	7.8		01/29/15	0.5	0.21	7.7	Bear Cove Reservoir		01/07/15	0.9	0.20	7.8	Bear Cove Reservoir			02/03/15	0.8	0.15	7.5	Bear Cove Reservoir		03/03/15	0.9	0.12	7.51		01/13/15	0.8	0.24	7.6	01/20/15	0.9	0.15	7.6		01/26/15	0.8	0.15	7.5	Ferry Terminal		01/07/15	0.5	0.25	7.6	Ferry Terminal			02/03/15	0.8	0.19	7.5	Ferry Terminal		03/03/15	0.7	0.13	7.4		01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6		01/26/15	0.7	0.13	7.6	Highway 19 PRV		01/07/15	1.0	0.26	7.5	Highway 19 PRV			02/03/15	0.9	0.18	7.6	Highway 19 PRV		03/03/15	1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6		01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																	
	01/26/15	1.1	0.25	7.6		Eagleview School	01/08/15	0.8	0.64	7.4			Eagleview School	02/03/15	0.8	0.13	7.9			Eagleview School	03/03/15	0.9	0.15	7.6			01/14/15	0.4	0.40	7.7		01/22/15	0.8	0.93	7.8	01/29/15	0.5	0.21	7.7	Bear Cove Reservoir	01/07/15	0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15	7.5			Bear Cove Reservoir	03/03/15	0.9	0.12	7.51			01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5			Ferry Terminal	03/03/15	0.7	0.13	7.4			01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6			Highway 19 PRV	03/03/15	1.1	0.17	7.4			01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																							
Eagleview School	01/08/15	0.8	0.64	7.4	Eagleview School		02/03/15	0.8	0.13	7.9		Eagleview School		03/03/15	0.9	0.15	7.6																																																																																																																																																																																																																																																																													
	01/14/15	0.4	0.40	7.7			01/22/15	0.8	0.93	7.8				01/29/15	0.5	0.21	7.7		Bear Cove Reservoir		01/07/15	0.9	0.20	7.8		Bear Cove Reservoir	02/03/15	0.8	0.15	7.5	Bear Cove Reservoir	03/03/15	0.9	0.12	7.51	01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15	7.6			01/26/15	0.8	0.15	7.5		Ferry Terminal		01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7	0.13	7.4	01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6			01/26/15	0.7	0.13	7.6		Highway 19 PRV		01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6			01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																												
	01/22/15	0.8	0.93	7.8			01/29/15	0.5	0.21	7.7	Bear Cove Reservoir			01/07/15	0.9	0.20	7.8	Bear Cove Reservoir			02/03/15	0.8	0.15	7.5	Bear Cove Reservoir		03/03/15	0.9	0.12	7.51		01/13/15	0.8	0.24	7.6	01/20/15	0.9	0.15	7.6		01/26/15	0.8	0.15	7.5	Ferry Terminal		01/07/15	0.5	0.25	7.6	Ferry Terminal			02/03/15	0.8	0.19	7.5	Ferry Terminal		03/03/15	0.7	0.13	7.4		01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6		01/26/15	0.7	0.13	7.6	Highway 19 PRV		01/07/15	1.0	0.26	7.5	Highway 19 PRV			02/03/15	0.9	0.18	7.6	Highway 19 PRV		03/03/15	1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6		01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																		
	01/29/15	0.5	0.21	7.7		Bear Cove Reservoir	01/07/15	0.9	0.20	7.8			Bear Cove Reservoir	02/03/15	0.8	0.15	7.5			Bear Cove Reservoir	03/03/15	0.9	0.12	7.51			01/13/15	0.8	0.24	7.6		01/20/15	0.9	0.15	7.6	01/26/15	0.8	0.15	7.5	Ferry Terminal	01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5			Ferry Terminal	03/03/15	0.7	0.13	7.4			01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6			Highway 19 PRV	03/03/15	1.1	0.17	7.4			01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																								
Bear Cove Reservoir	01/07/15	0.9	0.20	7.8	Bear Cove Reservoir		02/03/15	0.8	0.15	7.5		Bear Cove Reservoir		03/03/15	0.9	0.12	7.51																																																																																																																																																																																																																																																																													
	01/13/15	0.8	0.24	7.6			01/20/15	0.9	0.15	7.6				01/26/15	0.8	0.15	7.5		Ferry Terminal		01/07/15	0.5	0.25	7.6		Ferry Terminal	02/03/15	0.8	0.19	7.5	Ferry Terminal	03/03/15	0.7	0.13	7.4	01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6			01/26/15	0.7	0.13	7.6		Highway 19 PRV		01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6			01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																													
	01/20/15	0.9	0.15	7.6			01/26/15	0.8	0.15	7.5	Ferry Terminal			01/07/15	0.5	0.25	7.6	Ferry Terminal			02/03/15	0.8	0.19	7.5	Ferry Terminal		03/03/15	0.7	0.13	7.4		01/12/15	0.7	0.22	7.6	01/20/15	0.8	0.14	7.6		01/26/15	0.7	0.13	7.6	Highway 19 PRV		01/07/15	1.0	0.26	7.5	Highway 19 PRV			02/03/15	0.9	0.18	7.6	Highway 19 PRV		03/03/15	1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6		01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																			
	01/26/15	0.8	0.15	7.5		Ferry Terminal	01/07/15	0.5	0.25	7.6			Ferry Terminal	02/03/15	0.8	0.19	7.5			Ferry Terminal	03/03/15	0.7	0.13	7.4			01/12/15	0.7	0.22	7.6		01/20/15	0.8	0.14	7.6	01/26/15	0.7	0.13	7.6	Highway 19 PRV	01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6			Highway 19 PRV	03/03/15	1.1	0.17	7.4			01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																									
Ferry Terminal	01/07/15	0.5	0.25	7.6	Ferry Terminal		02/03/15	0.8	0.19	7.5		Ferry Terminal		03/03/15	0.7	0.13	7.4																																																																																																																																																																																																																																																																													
	01/12/15	0.7	0.22	7.6			01/20/15	0.8	0.14	7.6				01/26/15	0.7	0.13	7.6		Highway 19 PRV		01/07/15	1.0	0.26	7.5		Highway 19 PRV	02/03/15	0.9	0.18	7.6	Highway 19 PRV	03/03/15	1.1	0.17	7.4	01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6			01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																														
	01/20/15	0.8	0.14	7.6			01/26/15	0.7	0.13	7.6	Highway 19 PRV			01/07/15	1.0	0.26	7.5	Highway 19 PRV			02/03/15	0.9	0.18	7.6	Highway 19 PRV		03/03/15	1.1	0.17	7.4		01/13/15	1.0	0.21	7.7	01/20/15	1.1	0.34	8.6		01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																				
	01/26/15	0.7	0.13	7.6		Highway 19 PRV	01/07/15	1.0	0.26	7.5			Highway 19 PRV	02/03/15	0.9	0.18	7.6			Highway 19 PRV	03/03/15	1.1	0.17	7.4			01/13/15	1.0	0.21	7.7		01/20/15	1.1	0.34	8.6	01/26/15	1.0	0.13	7.5	Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																										
Highway 19 PRV	01/07/15	1.0	0.26	7.5	Highway 19 PRV		02/03/15	0.9	0.18	7.6		Highway 19 PRV		03/03/15	1.1	0.17	7.4																																																																																																																																																																																																																																																																													
	01/13/15	1.0	0.21	7.7			01/20/15	1.1	0.34	8.6				01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																																															
	01/20/15	1.1	0.34	8.6			01/26/15	1.0	0.13	7.5	Average			0.7	0.28	7.7	Average		0.8		0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																																																					
	01/26/15	1.0	0.13	7.5		Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6	Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4	Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																																																												
Average		0.7	0.28	7.7	Average		0.8	0.17	7.7	Average		0.8	0.18	7.6																																																																																																																																																																																																																																																																																
Minimum		0.2	0.13	7.4	Minimum		0.3	0.11	7.4	Minimum		0.3	0.11	7.4																																																																																																																																																																																																																																																																																
Maximum		1.2	0.93	8.6	Maximum		1.1	0.41	8.1	Maximum		1.1	0.40	8.1																																																																																																																																																																																																																																																																																

April					May					June																																																																																																																																																																																																																																																																																																																
Distribution Sampling					Distribution Sampling					Distribution Sampling																																																																																																																																																																																																																																																																																																																
Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH																																																																																																																																																																																																																																																																																																												
Chatham Avenue	04/01/15	0.6	0.18	7.8	Chatham Avenue	05/05/15	0.4	0.14	8.2	Chatham Avenue	06/02/15	0.5	0.13	7.8																																																																																																																																																																																																																																																																																																												
	04/07/15	0.5	0.12	7.8		04/08/15	0.5	0.13	7.9		04/14/15	0.6	0.12	7.9	04/21/15	0.8	0.14	7.9	04/29/15	0.5	0.22	8.0	Peel Street Liftstation	04/01/15	0.9	0.13	7.6	Peel Street Liftstation	05/05/15	0.7	0.20	7.6	Peel Street Liftstation	06/02/15	0.7	0.24	7.5	04/07/15	1.0	0.12	7.3	04/14/15	0.7	0.15	7.4	04/21/15	0.9	0.13	7.5	04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant	04/01/15	0.3	0.26	7.6	Airport Wastewater Treatment Plant	05/05/15	0.6	0.17	7.7	Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33	7.7	04/21/15	0.3	0.22	7.7	Public Works Yard	04/01/15	0.9	0.12	7.8	Public Works Yard	05/05/15	0.3	0.19	8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18	7.6	04/29/15	0.4	0.25	8.2	Eagleview School	04/01/15	0.6	0.26	7.8	Eagleview School	05/05/15	0.4	0.44	8.1	Eagleview School	06/02/15	0.3	0.18	8.0	04/07/15	0.8	0.87	7.7	04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir	05/05/15	0.6	0.14	7.7	Bear Cove Reservoir	06/02/15	0.7	0.31	7.6	04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19	7.8	Ferry Terminal	05/05/15	0.4	0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																										
	04/08/15	0.5	0.13	7.9		04/14/15	0.6	0.12	7.9		04/21/15	0.8	0.14	7.9	04/29/15	0.5	0.22	8.0	Peel Street Liftstation	04/01/15	0.9	0.13		7.6	Peel Street Liftstation	05/05/15	0.7		0.20	7.6	Peel Street Liftstation	06/02/15		0.7	0.24	7.5	04/07/15	1.0	0.12	7.3	04/14/15	0.7	0.15	7.4	04/21/15	0.9	0.13	7.5	04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant		04/01/15	0.3	0.26	7.6		Airport Wastewater Treatment Plant	05/05/15	0.6	0.17		7.7	Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33	7.7	04/21/15	0.3		0.22	7.7	Public Works Yard	04/01/15		0.9	0.12	7.8	Public Works Yard		05/05/15	0.3	0.19	8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18		7.6	04/29/15	0.4	0.25		8.2	Eagleview School	04/01/15	0.6		0.26	7.8	Eagleview School	05/05/15	0.4	0.44	8.1	Eagleview School	06/02/15	0.3	0.18	8.0	04/07/15	0.8	0.87	7.7		04/14/15	0.4	0.87	7.9		04/21/15	0.4	0.34	7.6		Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir	05/05/15	0.6	0.14	7.7	Bear Cove Reservoir	06/02/15	0.7	0.31	7.6	04/07/15		0.8	0.27	7.5	04/14/15		0.7	0.19	7.2	04/21/15		0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19	7.8	Ferry Terminal	05/05/15	0.4	0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7		0.14	7.6	04/14/15	0.4		0.20	7.6	04/21/15	0.4		0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																									
	04/14/15	0.6	0.12	7.9		04/21/15	0.8	0.14	7.9		04/29/15	0.5	0.22	8.0	Peel Street Liftstation	04/01/15	0.9	0.13		7.6	Peel Street Liftstation	05/05/15		0.7		0.20	7.6		Peel Street Liftstation	06/02/15		0.7		0.24	7.5	04/07/15	1.0	0.12	7.3	04/14/15	0.7	0.15	7.4	04/21/15	0.9	0.13	7.5	04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant			04/01/15	0.3	0.26	7.6			Airport Wastewater Treatment Plant	05/05/15	0.6		0.17		7.7	Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33	7.7		04/21/15	0.3		0.22		7.7	Public Works Yard	04/01/15			0.9	0.12	7.8	Public Works Yard		05/05/15	0.3	0.19	8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1		0.30	8.9	04/21/15	1.0		0.18		7.6	04/29/15		0.4	0.25		8.2	Eagleview School	04/01/15	0.6		0.26	7.8	Eagleview School	05/05/15	0.4	0.44	8.1	Eagleview School		06/02/15	0.3	0.18	8.0		04/07/15	0.8	0.87	7.7			04/14/15	0.4	0.87	7.9		04/21/15	0.4	0.34	7.6		Bear Cove Reservoir	04/01/15	0.9	0.16	7.5		Bear Cove Reservoir	05/05/15	0.6	0.14		7.7	Bear Cove Reservoir	06/02/15	0.7		0.31	7.6	04/07/15		0.8	0.27	7.5	04/14/15		0.7	0.19	7.2	04/21/15		0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6		0.19	7.8	Ferry Terminal	05/05/15		0.4	0.15	7.5	Ferry Terminal		06/02/15	0.4	0.13	7.5	04/07/15	0.7		0.14	7.6	04/14/15	0.4		0.20	7.6	04/21/15	0.4		0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1								
	04/21/15	0.8	0.14	7.9		04/29/15	0.5	0.22	8.0		Peel Street Liftstation	04/01/15	0.9	0.13		7.6	Peel Street Liftstation	05/05/15		0.7		0.20		7.6		Peel Street Liftstation	06/02/15			0.7		0.24		7.5	04/07/15	1.0	0.12	7.3	04/14/15	0.7	0.15	7.4	04/21/15	0.9	0.13	7.5	04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant				04/01/15	0.3	0.26	7.6				Airport Wastewater Treatment Plant	05/05/15		0.6		0.17		7.7	Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2		0.33	7.7		04/21/15		0.3		0.22			7.7	Public Works Yard	04/01/15			0.9	0.12	7.8	Public Works Yard		05/05/15	0.3	0.19	8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15		0.7	0.17	7.9	04/14/15		0.1		0.30	8.9		04/21/15	1.0		0.18		7.6	04/29/15		0.4	0.25		8.2	Eagleview School	04/01/15	0.6			0.26	7.8	Eagleview School	05/05/15		0.4	0.44	8.1	Eagleview School			06/02/15	0.3	0.18	8.0		04/07/15	0.8	0.87	7.7			04/14/15	0.4	0.87	7.9			04/21/15	0.4	0.34		7.6		Bear Cove Reservoir	04/01/15		0.9	0.16	7.5		Bear Cove Reservoir	05/05/15	0.6	0.14		7.7	Bear Cove Reservoir	06/02/15	0.7		0.31	7.6	04/07/15		0.8	0.27		7.5	04/14/15		0.7		0.19	7.2	04/21/15			0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6		0.19	7.8	Ferry Terminal	05/05/15		0.4	0.15	7.5	Ferry Terminal		06/02/15	0.4	0.13	7.5	04/07/15	0.7		0.14	7.6	04/14/15	0.4		0.20	7.6	04/21/15	0.4		0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum
	04/29/15	0.5	0.22	8.0		Peel Street Liftstation	04/01/15	0.9	0.13			7.6	Peel Street Liftstation	05/05/15		0.7		0.20		7.6		Peel Street Liftstation		06/02/15			0.7			0.24		7.5		04/07/15	1.0	0.12	7.3	04/14/15	0.7	0.15	7.4	04/21/15	0.9	0.13	7.5	04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant				04/01/15	0.3	0.26	7.6	Airport Wastewater Treatment Plant	05/05/15				0.6	0.17	7.7		Airport Wastewater Treatment Plant		06/02/15		0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33		7.7	04/21/15		0.3		0.22		7.7			Public Works Yard		04/01/15			0.9	0.12	7.8			Public Works Yard	05/05/15	0.3	0.19		8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1		0.30	8.9	04/21/15	1.0	0.18		7.6		04/29/15	0.4		0.25	8.2		Eagleview School		04/01/15	0.6		0.26	7.8	Eagleview School		05/05/15	0.4	0.44	8.1	Eagleview School		06/02/15		0.3	0.18	8.0	04/07/15		0.8	0.87	7.7	04/14/15			0.4	0.87	7.9	04/21/15			0.4	0.34	7.6		Bear Cove Reservoir			04/01/15		0.9	0.16	7.5			Bear Cove Reservoir	05/05/15	0.6		0.14		7.7	Bear Cove Reservoir		06/02/15	0.7	0.31		7.6	04/07/15		0.8	0.27		7.5		04/14/15	0.7	0.19			7.2	04/21/15	0.9		0.15	7.5		Ferry Terminal	04/01/15		0.6		0.19	7.8	Ferry Terminal			05/05/15	0.4	0.15	7.5	Ferry Terminal	06/02/15		0.4	0.13	7.5	04/07/15		0.7	0.14	7.6	04/14/15		0.4	0.20	7.6	04/21/15	0.4	0.12		7.5	04/29/15	0.5	0.19		7.6	Highway 19 PRV	04/01/15	1.0		0.39	7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2
Peel Street Liftstation	04/01/15	0.9	0.13	7.6	Peel Street Liftstation		05/05/15	0.7	0.20	7.6		Peel Street Liftstation		06/02/15		0.7		0.24		7.5																																																																																																																																																																																																																																																																																																						
	04/07/15	1.0	0.12	7.3			04/14/15	0.7	0.15	7.4				04/21/15		0.9		0.13	7.5	04/29/15			0.6	0.25	7.8		Airport Wastewater Treatment Plant	04/01/15		0.3	0.26	7.6	Airport Wastewater Treatment Plant	05/05/15	0.6	0.17	7.7	Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5	04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33			7.7	04/21/15	0.3	0.22	7.7	Public Works Yard		04/01/15	0.9	0.12		7.8	Public Works Yard	05/05/15	0.3		0.19	8.8		Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18	7.6		04/29/15	0.4	0.25			8.2		Eagleview School	04/01/15	0.6	0.26				7.8	Eagleview School	05/05/15		0.4		0.44	8.1	Eagleview School	06/02/15	0.3	0.18	8.0	04/07/15	0.8	0.87	7.7	04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir			05/05/15	0.6	0.14	7.7	Bear Cove Reservoir			06/02/15	0.7	0.31	7.6			04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19	7.8	Ferry Terminal	05/05/15	0.4	0.15	7.5	Ferry Terminal		06/02/15		0.4	0.13	7.5	04/07/15	0.7	0.14			7.6	04/14/15	0.4	0.20		7.6		04/21/15	0.4	0.12	7.5		04/29/15	0.5	0.19	7.6	Highway 19 PRV		04/01/15	1.0	0.39	7.3	Highway 19 PRV		05/05/15	0.8	0.14	7.6		Highway 19 PRV	06/02/15	0.9		0.19		7.5	04/07/15	1.0	0.19			7.5	04/14/15	0.9	0.18	7.5		04/21/15		1.0	0.17	7.6	04/29/15		0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4		0.19	8.0	Average			0.5		0.21	7.7		Minimum			0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																									
	04/14/15	0.7	0.15	7.4			04/21/15	0.9	0.13	7.5				04/29/15	0.6	0.25		7.8	Airport Wastewater Treatment Plant	04/01/15	0.3		0.26	7.6	Airport Wastewater Treatment Plant			05/05/15	0.6	0.17	7.7	Airport Wastewater Treatment Plant		06/02/15	0.8	0.20	7.5		04/07/15	0.8	0.21	7.6	04/14/15	0.2	0.33	7.7	04/21/15	0.3	0.22		7.7	Public Works Yard	04/01/15	0.9	0.12	7.8			Public Works Yard	05/05/15	0.3	0.19	8.8		Public Works Yard	06/02/15		0.2	0.74	7.7		04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18	7.6	04/29/15	0.4	0.25	8.2	Eagleview School	04/01/15	0.6	0.26			7.8	Eagleview School		05/05/15	0.4	0.44		8.1		Eagleview School		06/02/15		0.3		0.18	8.0		04/07/15	0.8	0.87	7.7	04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16		7.5	Bear Cove Reservoir	05/05/15	0.6			0.14	7.7	Bear Cove Reservoir	06/02/15	0.7			0.31	7.6	04/07/15	0.8	0.27		7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19		7.8	Ferry Terminal	05/05/15	0.4		0.15	7.5	Ferry Terminal	06/02/15			0.4	0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4		0.20	7.6	04/21/15	0.4	0.12	7.5		04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3		Highway 19 PRV	05/05/15	0.8	0.14	7.6		Highway 19 PRV	06/02/15	0.9	0.19	7.5			04/07/15	1.0		0.19		7.5	04/14/15	0.9	0.18			7.5	04/21/15	1.0	0.17	7.6		04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21		7.7	Minimum		0.1		0.12		7.2	Minimum		0.1	0.12		7.4	Minimum		0.2		0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																															
	04/21/15	0.9	0.13	7.5			04/29/15	0.6	0.25	7.8	Airport Wastewater Treatment Plant			04/01/15	0.3	0.26	7.6	Airport Wastewater Treatment Plant		05/05/15	0.6		0.17	7.7		Airport Wastewater Treatment Plant		06/02/15	0.8	0.20	7.5			04/07/15	0.8	0.21	7.6		04/14/15	0.2	0.33	7.7	04/21/15	0.3	0.22	7.7	Public Works Yard	04/01/15	0.9	0.12	7.8		Public Works Yard	05/05/15	0.3	0.19		8.8		Public Works Yard	06/02/15	0.2	0.74			7.7	04/07/15	0.7	0.17	7.9		04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18	7.6	04/29/15	0.4	0.25	8.2	Eagleview School	04/01/15	0.6	0.26		7.8	Eagleview School	05/05/15		0.4	0.44			8.1	Eagleview School	06/02/15	0.3	0.18				8.0	04/07/15	0.8		0.87	7.7		04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16		7.5	Bear Cove Reservoir	05/05/15		0.6		0.14	7.7		Bear Cove Reservoir	06/02/15	0.7		0.31	7.6		04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19		7.8	Ferry Terminal	05/05/15		0.4		0.15	7.5		Ferry Terminal	06/02/15		0.4		0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39		7.3	Highway 19 PRV	05/05/15	0.8			0.14	7.6	Highway 19 PRV	06/02/15			0.9	0.19	7.5	04/07/15	1.0		0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15	1.0		0.17	7.6	04/29/15	0.7	0.18	7.6		Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4		Minimum		0.2	0.12	7.3		Maximum		1.0	0.87		8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																					
	04/29/15	0.6	0.25	7.8		Airport Wastewater Treatment Plant	04/01/15	0.3	0.26	7.6			Airport Wastewater Treatment Plant	05/05/15	0.6	0.17	7.7			Airport Wastewater Treatment Plant	06/02/15	0.8	0.20	7.5				04/07/15	0.8	0.21	7.6			04/14/15	0.2	0.33	7.7		04/21/15	0.3	0.22	7.7	Public Works Yard	04/01/15	0.9	0.12		7.8	Public Works Yard	05/05/15	0.3			0.19	8.8	Public Works Yard		06/02/15			0.2	0.74	7.7			04/07/15	0.7	0.17	7.9	04/14/15		0.1	0.30	8.9	04/21/15	1.0	0.18	7.6	04/29/15	0.4	0.25	8.2	Eagleview School		04/01/15	0.6	0.26		7.8		Eagleview School	05/05/15	0.4	0.44			8.1		Eagleview School	06/02/15	0.3	0.18			8.0	04/07/15	0.8	0.87	7.7	04/14/15		0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir		04/01/15	0.9	0.16		7.5		Bear Cove Reservoir		05/05/15		0.6	0.14			7.7	Bear Cove Reservoir		06/02/15	0.7		0.31	7.6	04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9		0.15	7.5	Ferry Terminal		04/01/15		0.6		0.19		7.8	Ferry Terminal			05/05/15		0.4		0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12		7.5	04/29/15	0.5		0.19		7.6	Highway 19 PRV			04/01/15	1.0		0.39			7.3	Highway 19 PRV	05/05/15	0.8	0.14		7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																			
Airport Wastewater Treatment Plant	04/01/15	0.3	0.26	7.6	Airport Wastewater Treatment Plant		05/05/15	0.6	0.17	7.7		Airport Wastewater Treatment Plant		06/02/15	0.8	0.20	7.5																																																																																																																																																																																																																																																																																																									
	04/07/15	0.8	0.21	7.6			04/14/15	0.2	0.33	7.7				04/21/15	0.3	0.22	7.7		Public Works Yard		04/01/15	0.9	0.12	7.8	Public Works Yard		05/05/15	0.3	0.19	8.8	Public Works Yard	06/02/15	0.2	0.74	7.7	04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30		8.9	04/21/15	1.0		0.18		7.6	04/29/15			0.4	0.25		8.2	Eagleview School			04/01/15	0.6	0.26	7.8		Eagleview School	05/05/15	0.4	0.44	8.1	Eagleview School	06/02/15	0.3	0.18	8.0	04/07/15	0.8	0.87	7.7	04/14/15	0.4	0.87			7.9	04/21/15	0.4	0.34	7.6			Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir			05/05/15	0.6	0.14	7.7	Bear Cove Reservoir	06/02/15	0.7	0.31	7.6	04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9			0.15	7.5	Ferry Terminal	04/01/15	0.6			0.19	7.8	Ferry Terminal	05/05/15	0.4	0.15		7.5		Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12		7.5	04/29/15			0.5		0.19	7.6	Highway 19 PRV		04/01/15		1.0		0.39		7.3	Highway 19 PRV	05/05/15	0.8		0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5		04/21/15	1.0	0.17		7.6		04/29/15		0.7		0.18	7.6		Average			0.6		0.24	7.7	Average		0.4		0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																															
	04/14/15	0.2	0.33	7.7			04/21/15	0.3	0.22	7.7	Public Works Yard			04/01/15	0.9	0.12	7.8	Public Works Yard			05/05/15	0.3	0.19	8.8		Public Works Yard	06/02/15	0.2	0.74	7.7		04/07/15	0.7	0.17	7.9	04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18		7.6	04/29/15	0.4		0.25		8.2	Eagleview School	04/01/15		0.6	0.26		7.8		Eagleview School		05/05/15	0.4	0.44	8.1	Eagleview School		06/02/15	0.3	0.18	8.0		04/07/15	0.8	0.87	7.7	04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34		7.6	Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir			05/05/15	0.6	0.14	7.7		Bear Cove Reservoir		06/02/15	0.7	0.31	7.6		04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15		0.6	0.19	7.8		Ferry Terminal	05/05/15	0.4		0.15	7.5		Ferry Terminal	06/02/15	0.4	0.13	7.5			04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19		7.6	Highway 19 PRV		04/01/15	1.0		0.39	7.3		Highway 19 PRV	05/05/15		0.8		0.14	7.6	Highway 19 PRV		06/02/15	0.9		0.19	7.5		04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6		04/29/15	0.7	0.18	7.6	Average		0.6		0.24	7.7	Average			0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum			0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																								
	04/21/15	0.3	0.22	7.7		Public Works Yard	04/01/15	0.9	0.12	7.8			Public Works Yard	05/05/15	0.3	0.19	8.8			Public Works Yard	06/02/15	0.2	0.74	7.7			04/07/15	0.7	0.17	7.9		04/14/15	0.1	0.30	8.9	04/21/15	1.0	0.18	7.6	04/29/15	0.4	0.25		8.2	Eagleview School	04/01/15	0.6	0.26		7.8		Eagleview School	05/05/15	0.4	0.44		8.1			Eagleview School	06/02/15	0.3	0.18	8.0			04/07/15	0.8	0.87	7.7		04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16	7.5		Bear Cove Reservoir	05/05/15	0.6	0.14		7.7		Bear Cove Reservoir	06/02/15	0.7	0.31			7.6	04/07/15	0.8	0.27	7.5		04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19		7.8	Ferry Terminal	05/05/15	0.4	0.15			7.5	Ferry Terminal	06/02/15	0.4	0.13			7.5	04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15	1.0	0.39	7.3			Highway 19 PRV	05/05/15	0.8	0.14	7.6			Highway 19 PRV		06/02/15	0.9	0.19	7.5			04/07/15	1.0		0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4		0.19	8.0	Average		0.5	0.21	7.7	Minimum			0.1	0.12	7.2	Minimum			0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																													
Public Works Yard	04/01/15	0.9	0.12	7.8	Public Works Yard		05/05/15	0.3	0.19	8.8		Public Works Yard		06/02/15	0.2	0.74	7.7																																																																																																																																																																																																																																																																																																									
	04/07/15	0.7	0.17	7.9			04/14/15	0.1	0.30	8.9				04/21/15	1.0	0.18	7.6				04/29/15	0.4	0.25	8.2			Eagleview School	04/01/15	0.6	0.26		7.8	Eagleview School	05/05/15	0.4	0.44	8.1	Eagleview School	06/02/15	0.3	0.18	8.0	04/07/15	0.8		0.87	7.7	04/14/15	0.4	0.87			7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir			04/01/15	0.9	0.16	7.5		Bear Cove Reservoir	05/05/15	0.6	0.14	7.7	Bear Cove Reservoir	06/02/15	0.7	0.31	7.6	04/07/15	0.8	0.27	7.5		04/14/15	0.7	0.19	7.2			04/21/15	0.9	0.15		7.5	Ferry Terminal		04/01/15	0.6	0.19	7.8		Ferry Terminal	05/05/15	0.4	0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20		7.6		04/21/15	0.4	0.12			7.5		04/29/15	0.5	0.19			7.6	Highway 19 PRV	04/01/15	1.0	0.39		7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15		1.0	0.19	7.5	04/14/15		0.9		0.18	7.5	04/21/15	1.0				0.17	7.6	04/29/15	0.7	0.18			7.6	Average		0.6	0.24		7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																
	04/14/15	0.1	0.30	8.9			04/21/15	1.0	0.18	7.6				04/29/15	0.4	0.25	8.2		Eagleview School		04/01/15	0.6	0.26	7.8	Eagleview School			05/05/15	0.4	0.44	8.1	Eagleview School		06/02/15	0.3	0.18	8.0		04/07/15	0.8	0.87	7.7	04/14/15	0.4		0.87	7.9	04/21/15	0.4	0.34	7.6		Bear Cove Reservoir	04/01/15	0.9	0.16	7.5		Bear Cove Reservoir		05/05/15	0.6	0.14	7.7	Bear Cove Reservoir		06/02/15	0.7	0.31	7.6		04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2		04/21/15	0.9	0.15	7.5	Ferry Terminal		04/01/15	0.6	0.19	7.8	Ferry Terminal			05/05/15	0.4	0.15	7.5	Ferry Terminal		06/02/15	0.4	0.13	7.5		04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6		04/21/15	0.4	0.12		7.5		04/29/15	0.5	0.19	7.6		Highway 19 PRV		04/01/15	1.0	0.39	7.3		Highway 19 PRV		05/05/15	0.8	0.14	7.6	Highway 19 PRV		06/02/15	0.9	0.19	7.5		04/07/15	1.0	0.19	7.5	04/14/15		0.9	0.18	7.5	04/21/15		1.0		0.17	7.6	04/29/15	0.7	0.18			7.6	Average		0.6	0.24		7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																							
	04/21/15	1.0	0.18	7.6			04/29/15	0.4	0.25	8.2	Eagleview School			04/01/15	0.6	0.26	7.8	Eagleview School			05/05/15	0.4	0.44	8.1		Eagleview School		06/02/15	0.3	0.18	8.0			04/07/15	0.8	0.87	7.7		04/14/15	0.4	0.87	7.9	04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir		05/05/15	0.6	0.14	7.7			Bear Cove Reservoir	06/02/15	0.7	0.31	7.6			04/07/15	0.8	0.27	7.5		04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19	7.8		Ferry Terminal	05/05/15	0.4	0.15	7.5			Ferry Terminal	06/02/15	0.4	0.13	7.5			04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5		04/29/15	0.5	0.19	7.6	Highway 19 PRV		04/01/15	1.0	0.39	7.3	Highway 19 PRV			05/05/15	0.8	0.14	7.6	Highway 19 PRV			06/02/15	0.9	0.19	7.5			04/07/15	1.0	0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15		1.0	0.17	7.6	04/29/15	0.7	0.18		7.6	Average		0.6	0.24	7.7		Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																														
	04/29/15	0.4	0.25	8.2		Eagleview School	04/01/15	0.6	0.26	7.8			Eagleview School	05/05/15	0.4	0.44	8.1			Eagleview School	06/02/15	0.3	0.18	8.0				04/07/15	0.8	0.87	7.7			04/14/15	0.4	0.87	7.9		04/21/15	0.4	0.34	7.6	Bear Cove Reservoir	04/01/15	0.9	0.16		7.5	Bear Cove Reservoir	05/05/15	0.6			0.14	7.7	Bear Cove Reservoir	06/02/15				0.7	0.31	7.6	04/07/15			0.8	0.27	7.5	04/14/15		0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal		04/01/15	0.6	0.19	7.8			Ferry Terminal	05/05/15	0.4	0.15				7.5	Ferry Terminal	06/02/15	0.4			0.13	7.5	04/07/15	0.7		0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19		7.6	Highway 19 PRV	04/01/15	1.0	0.39			7.3	Highway 19 PRV	05/05/15	0.8	0.14				7.6	Highway 19 PRV	06/02/15	0.9			0.19	7.5	04/07/15	1.0		0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																															
Eagleview School	04/01/15	0.6	0.26	7.8	Eagleview School		05/05/15	0.4	0.44	8.1		Eagleview School		06/02/15	0.3	0.18	8.0																																																																																																																																																																																																																																																																																																									
	04/07/15	0.8	0.87	7.7			04/14/15	0.4	0.87	7.9				04/21/15	0.4	0.34	7.6		Bear Cove Reservoir		04/01/15	0.9	0.16	7.5	Bear Cove Reservoir		05/05/15	0.6	0.14	7.7	Bear Cove Reservoir	06/02/15	0.7	0.31	7.6	04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19		7.2	04/21/15	0.9		0.15		7.5	Ferry Terminal		04/01/15	0.6	0.19		7.8	Ferry Terminal	05/05/15		0.4	0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4			0.12	7.5	04/29/15	0.5				0.19	7.6	Highway 19 PRV		04/01/15		1.0		0.39	7.3		Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15		1.0		0.17	7.6	04/29/15			0.7		0.18	7.6	Average			0.6	0.24		7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																										
	04/14/15	0.4	0.87	7.9			04/21/15	0.4	0.34	7.6	Bear Cove Reservoir			04/01/15	0.9	0.16	7.5	Bear Cove Reservoir			05/05/15	0.6	0.14	7.7		Bear Cove Reservoir	06/02/15	0.7	0.31	7.6		04/07/15	0.8	0.27	7.5	04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15		7.5	Ferry Terminal	04/01/15	0.6	0.19		7.8		Ferry Terminal	05/05/15	0.4	0.15		7.5		Ferry Terminal	06/02/15	0.4	0.13	7.5		04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5			0.19	7.6	Highway 19 PRV	04/01/15	1.0			0.39	7.3		Highway 19 PRV	05/05/15		0.8		0.14	7.6	Highway 19 PRV		06/02/15	0.9	0.19	7.5		04/07/15	1.0	0.19	7.5	04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15		0.7		0.18	7.6	Average		0.6	0.24		7.7	Average			0.4	0.19	8.0		Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																
	04/21/15	0.4	0.34	7.6		Bear Cove Reservoir	04/01/15	0.9	0.16	7.5			Bear Cove Reservoir	05/05/15	0.6	0.14	7.7			Bear Cove Reservoir	06/02/15	0.7	0.31	7.6			04/07/15	0.8	0.27	7.5		04/14/15	0.7	0.19	7.2	04/21/15	0.9	0.15	7.5	Ferry Terminal	04/01/15	0.6	0.19	7.8		Ferry Terminal	05/05/15	0.4	0.15	7.5			Ferry Terminal	06/02/15	0.4	0.13	7.5			04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5	04/29/15	0.5	0.19	7.6	Highway 19 PRV	04/01/15		1.0	0.39	7.3		Highway 19 PRV	05/05/15	0.8		0.14	7.6			Highway 19 PRV	06/02/15	0.9		0.19	7.5			04/07/15	1.0	0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6		0.24	7.7	Average		0.4	0.19		8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																							
Bear Cove Reservoir	04/01/15	0.9	0.16	7.5	Bear Cove Reservoir		05/05/15	0.6	0.14	7.7		Bear Cove Reservoir		06/02/15	0.7	0.31	7.6																																																																																																																																																																																																																																																																																																									
	04/07/15	0.8	0.27	7.5			04/14/15	0.7	0.19	7.2				04/21/15	0.9	0.15	7.5		Ferry Terminal		04/01/15	0.6	0.19	7.8	Ferry Terminal		05/05/15	0.4	0.15	7.5	Ferry Terminal	06/02/15	0.4	0.13	7.5	04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20	7.6			04/21/15	0.4	0.12	7.5				04/29/15	0.5	0.19	7.6			Highway 19 PRV	04/01/15	1.0	0.39		7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15		1.0	0.19	7.5	04/14/15	0.9			0.18	7.5	04/21/15	1.0	0.17				7.6	04/29/15	0.7	0.18	7.6			Average		0.6	0.24		7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																									
	04/14/15	0.7	0.19	7.2			04/21/15	0.9	0.15	7.5	Ferry Terminal			04/01/15	0.6	0.19	7.8	Ferry Terminal			05/05/15	0.4	0.15	7.5		Ferry Terminal	06/02/15	0.4	0.13	7.5		04/07/15	0.7	0.14	7.6	04/14/15	0.4	0.20	7.6		04/21/15	0.4	0.12	7.5			04/29/15	0.5	0.19	7.6	Highway 19 PRV			04/01/15	1.0	0.39	7.3	Highway 19 PRV			05/05/15	0.8	0.14	7.6	Highway 19 PRV		06/02/15	0.9	0.19	7.5		04/07/15	1.0	0.19	7.5	04/14/15		0.9	0.18	7.5	04/21/15	1.0			0.17	7.6	04/29/15	0.7	0.18	7.6			Average		0.6	0.24	7.7		Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																
	04/21/15	0.9	0.15	7.5		Ferry Terminal	04/01/15	0.6	0.19	7.8			Ferry Terminal	05/05/15	0.4	0.15	7.5			Ferry Terminal	06/02/15	0.4	0.13	7.5			04/07/15	0.7	0.14	7.6		04/14/15	0.4	0.20	7.6	04/21/15	0.4	0.12	7.5		04/29/15	0.5	0.19	7.6	Highway 19 PRV		04/01/15	1.0	0.39	7.3		Highway 19 PRV		05/05/15	0.8	0.14	7.6		Highway 19 PRV		06/02/15	0.9	0.19	7.5			04/07/15	1.0	0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15		1.0	0.17	7.6	04/29/15	0.7	0.18		7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																								
Ferry Terminal	04/01/15	0.6	0.19	7.8	Ferry Terminal		05/05/15	0.4	0.15	7.5		Ferry Terminal		06/02/15	0.4	0.13	7.5																																																																																																																																																																																																																																																																																																									
	04/07/15	0.7	0.14	7.6			04/14/15	0.4	0.20	7.6				04/21/15	0.4	0.12	7.5				04/29/15	0.5	0.19	7.6			Highway 19 PRV	04/01/15	1.0	0.39		7.3	Highway 19 PRV	05/05/15	0.8	0.14	7.6	Highway 19 PRV	06/02/15	0.9	0.19	7.5	04/07/15	1.0		0.19	7.5	04/14/15	0.9	0.18			7.5	04/21/15	1.0	0.17	7.6				04/29/15	0.7	0.18	7.6			Average		0.6	0.24		7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																										
	04/14/15	0.4	0.20	7.6			04/21/15	0.4	0.12	7.5				04/29/15	0.5	0.19	7.6		Highway 19 PRV		04/01/15	1.0	0.39	7.3	Highway 19 PRV			05/05/15	0.8	0.14	7.6	Highway 19 PRV		06/02/15	0.9	0.19	7.5		04/07/15	1.0	0.19	7.5	04/14/15	0.9		0.18	7.5	04/21/15	1.0	0.17			7.6	04/29/15	0.7	0.18	7.6			Average		0.6	0.24	7.7		Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																	
	04/21/15	0.4	0.12	7.5			04/29/15	0.5	0.19	7.6	Highway 19 PRV			04/01/15	1.0	0.39	7.3	Highway 19 PRV			05/05/15	0.8	0.14	7.6		Highway 19 PRV		06/02/15	0.9	0.19	7.5			04/07/15	1.0	0.19	7.5		04/14/15	0.9	0.18	7.5	04/21/15	1.0		0.17	7.6	04/29/15	0.7	0.18	7.6		Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																									
	04/29/15	0.5	0.19	7.6		Highway 19 PRV	04/01/15	1.0	0.39	7.3			Highway 19 PRV	05/05/15	0.8	0.14	7.6			Highway 19 PRV	06/02/15	0.9	0.19	7.5				04/07/15	1.0	0.19	7.5			04/14/15	0.9	0.18	7.5		04/21/15	1.0	0.17	7.6	04/29/15	0.7	0.18	7.6	Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																															
Highway 19 PRV	04/01/15	1.0	0.39	7.3	Highway 19 PRV		05/05/15	0.8	0.14	7.6		Highway 19 PRV		06/02/15	0.9	0.19	7.5																																																																																																																																																																																																																																																																																																									
	04/07/15	1.0	0.19	7.5			04/14/15	0.9	0.18	7.5				04/21/15	1.0	0.17	7.6				04/29/15	0.7	0.18	7.6			Average		0.6	0.24	7.7		Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																																																		
	04/14/15	0.9	0.18	7.5			04/21/15	1.0	0.17	7.6				04/29/15	0.7	0.18	7.6		Average		0.6	0.24	7.7	Average			0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																																																										
	04/21/15	1.0	0.17	7.6			04/29/15	0.7	0.18	7.6	Average			0.6	0.24	7.7	Average		0.4		0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																																																																	
	04/29/15	0.7	0.18	7.6		Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7	Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3	Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																																																																								
Average		0.6	0.24	7.7	Average		0.4	0.19	8.0	Average		0.5	0.21	7.7																																																																																																																																																																																																																																																																																																												
Minimum		0.1	0.12	7.2	Minimum		0.1	0.12	7.4	Minimum		0.2	0.12	7.3																																																																																																																																																																																																																																																																																																												
Maximum		1.0	0.87	8.9	Maximum		0.8	0.44	8.9	Maximum		0.9	0.93	8.1																																																																																																																																																																																																																																																																																																												

DISTRICT OF PORT HARDY

WATER SYSTEM ANNUAL REPORT 2015



July					August					September				
Distribution Sampling					Distribution Sampling					Distribution Sampling				
Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH	Location	Date	Free Chlorine mg/L	Turbidity NTU	pH
Chatham Avenue	07/07/15	0.6	0.14	7.9										
	07/14/15	0.4	0.12	7.8										
	07/22/15	0.4	0.13	7.8										
	07/28/15	0.1	0.13	7.8										
Peel Street Lifestation	07/07/15	0.7	0.20	7.8										
	07/14/15	0.7	0.14	7.5										
	07/22/15	0.7	0.12	7.5										
	07/28/15	0.5	0.20	7.4										
Airport Wastewater Treatment Plant	07/07/15	0.2	0.19	7.7										
	07/14/15	0.2	0.27	7.9										
	07/22/15	0.1	0.34	7.7										
	07/28/15	0.1	0.30	7.7										
Public Works Yard	07/07/15	0.8	0.14	7.7										
	07/14/15	0.4	0.12	8.0										
	07/22/15	0.4	0.14	8.0										
	07/28/15	0.1	0.14	8.6										
Eagleview School	07/07/15	0.5	0.14	7.7										
	07/14/15	0.3	0.12	7.7										
	07/22/15	0.3	0.13	7.7										
	07/28/15	0.2	0.20	7.4										
Bear Cove Reservoir	07/07/15	0.5	0.15	7.7										
	07/14/15	0.6	0.13	7.7										
	07/22/15	0.5	0.16	7.6										
	07/28/15	0.5	0.24	7.4										
Ferry Terminal	07/07/15	0.7	0.13	7.6										
	07/14/15	0.5	0.14	7.5										
	07/22/15	0.5	0.21	7.5										
	07/28/15	0.3	0.17	7.4										
Highway 19 PRV	07/07/15	0.9	0.23	7.7										
	07/14/15	0.9	0.18	7.6										
	07/22/15	0.8	0.17	7.7										
	07/28/15	0.6	0.18	7.4										
Average		0.5	0.17	7.7										
Minimum		0.1	0.34	7.4										
Maximum		0.9	0.34	8.6										
Chatham Avenue	08/04/15	0.3	0.06	7.7										
	08/11/15	0.2	0.13	7.7										
	08/18/15	0.4	0.06	7.7										
	08/27/15	0.4	0.12	7.7										
Peel Street Lifestation	08/04/15	0.6	0.11	7.6										
	08/11/15	0.6	0.18	7.6										
	08/18/15	0.5	0.37	7.4										
	08/27/15	0.6	0.46	7.5										
Airport Wastewater Treatment Plant	08/04/15	0.1	0.18	7.6										
	08/11/15	0.2	0.31	7.6										
	08/18/15	0.1	0.33	7.3										
	08/27/15	0.2	0.35	7.7										
Public Works Yard	08/04/15	0.4	0.06	7.6										
	08/11/15	0.4	0.19	7.9										
	08/18/15	0.2	0.12	7.8										
	08/27/15	0.3	0.14	7.8										
Eagleview School	08/04/15	0.2	0.21	7.5										
	08/11/15	0.3	0.12	7.7										
	08/18/15	0.4	0.13	7.7										
	08/27/15	0.5	0.15	7.7										
Bear Cove Reservoir	08/04/15	0.8	0.19	7.5										
	08/11/15	0.4	0.42	7.6										
	08/18/15	0.5	0.24	7.6										
	08/27/15	0.5	0.25	7.5										
Ferry Terminal	08/04/15	0.2	0.09	7.5										
	08/11/15	0.3	0.31	7.6										
	08/18/15	0.6	0.17	7.6										
	08/27/15	0.6	0.26	7.5										
Highway 19 PRV	08/04/15	0.9	0.15	7.4										
	08/11/15	0.8	0.19	7.8										
	08/18/15	1.0	0.39	7.6										
	08/27/15	0.9	0.19	7.5										
Average		0.4	0.21	7.6										
Minimum		0.1	0.06	7.3										
Maximum		1.0	0.46	7.9										
Chatham Avenue	09/01/15	0.3	0.17	7.7										
	09/08/15	0.4	0.12											
	09/15/15	0.3	0.11	7.9										
	09/23/15	0.4	0.19	7.9										
	09/29/15	0.4	0.15	7.9										
	09/01/15	0.4	0.27	7.2										
	09/08/15	0.7	0.17	7.5										
	09/15/15	0.8	0.20	7.6										
	09/22/15	0.8	0.28	7.7										
	09/29/15	0.6	0.12	7.6										
	09/01/15	0.2	0.21	7.5										
Peel Street Lifestation	09/08/15	0.3	0.18	7.5										
	09/15/15	0.0	1.27	7.6										
	09/22/15	0.6	0.28	7.7										
	09/29/15	0.0	0.19	7.6										
	09/01/15	0.2	0.17	7.9										
	09/08/15	0.2	0.16	8.9										
	09/15/15	0.2	0.09	8.4										
	09/23/15	0.1	0.25	8.3										
	09/29/15	0.3	0.14	7.8										
	09/08/15	0.2	0.52	8.6										
	09/15/15	0.6	1.96	7.9										
Airport Wastewater Treatment Plant	09/23/15	0.2	0.23	8.2										
	09/29/15	0.1	0.21	8.3										
	09/01/15	0.5	0.20	7.6										
	09/08/15	0.4	0.18	7.5										
	09/15/15	0.5	0.15	7.6										
	09/23/15	0.6	0.18	7.6										
	09/29/15	0.5	0.14	7.5										
	09/01/15	0.4	0.22											
	09/08/15	0.2	0.44	7.5										
	09/15/15	0.1	0.12	7.5										
	09/23/15	0.2	0.14	7.6										
09/29/15	0.3	0.09	7.6											
Public Works Yard	09/01/15	0.7	0.21											
	09/08/15	0.8	0.21	7.5										
	09/15/15	1.0	0.15	7.7										
	09/23/15	0.9	0.32	7.6										
	09/29/15	0.8	0.39	7.8										
	Average		0.4	0.27	7.8									
	Minimum		0.0	0.09	7.2									
	Maximum		1.0	1.96	8.9									
	Chatham Avenue	10/06/15	0.4	0.11	7.8									
		10/13/15	0.5	0.11	7.9									
		10/20/15	0.5	0.14	7.7									
10/27/15		0.1	0.27	7.4										
Peel Street Lifestation	10/06/15	0.7	0.12	7.5										
	10/13/15	0.6	0.12	7.7										
	10/20/15	0.6	0.11	7.7										
	10/27/15	0.8	0.13	7.6										
Airport Wastewater Treatment Plant	10/06/15	0.5	0.20	7.7										
	10/13/15	0.2	0.20	8.2										
	10/20/15	0.6	0.16	7.6										
	10/27/15	0.1	0.19	7.7										
Public Works Yard	10/06/15	0.7	0.14	8.1										
	10/13/15	0.3	0.24	8.3										
	10/20/15	0.8	0.14	7.9										
	10/27/15	0.6	0.13	8.0										
Eagleview School	10/06/15	0.2	0.49	7.7										
	10/13/15	0.2	0.31	7.8										
	10/20/15	0.2	0.39	7.6										
	10/27/15	0.3	0.48	7.9										
Bear Cove Reservoir	10/06/15	0.6	0.16	7.5										
	10/13/15	0.5	0.16	7.6										
	10/20/15	0.8	0.15	7.7										
	10/27/15	0.7	0.14	7.6										
Ferry Terminal	10/06/15	0.3	0.12	7.6										
	10/13/15	0.5	0.14	7.7										
	10/20/15	0.6	0.13	7.6										
	10/27/15	0.5	0.14	7.6										
Highway 19 PRV	10/06/15	0.8	0.12	7.6										
	10/13/15	0.8	0.11	7.7										
	10/20/15	0.9	0.11	7.6										
	10/27/15	0.9	0.12	7.7										
Average		0.5	0.11	7.7										
Minimum		0.1	0.49	7.4										
Maximum		0.8	0.49	8.3										
Chatham Avenue	11/03/15	0.6	0.11	7.9										
	11/10/15	0.7	0.15	7.6										
	11/17/15	0.4	0.12	7.9										
	11/24/15	0.6	0.14	7.5										
Peel Street Lifestation	11/03/15	0.8	0.13	7.5										
	11/10/15	0.9	0.13	7.5										
	11/17/15	0.7	0.13	7.5										
	11/24/15	0.7	0.14	7.5										
Airport Wastewater Treatment Plant	11/03/15	0.1	0.60	7.6										
	11/10/15	0.1	0.41	7.8										
	11/17/15	0.7	0.18	7.6										
	11/24/15	0.3	0.35	7.6										
Public Works Yard	11/03/15	0.9	0.35	7.4										
	11/10/15	0.7	0.17	7.7										
	11/17/15	0.3	0.14	8.2										
	11/24/15	0.8	0.20	7.6										
Eagleview School	11/03/15	0.8	0.72	7.4										
	11/10/15	0.2	0.51	7.6										
	11/18/15	0.3	0.26	7.8										
	11/24/15	0.2	0.19	7.7										
Bear Cove Reservoir	11/03/15	0.7	0.16	7.7										
	11/10/15	0.6	0.21	7.6										
	11/18/15	0.8	0.11	7.6										
	11/24/15	0.5	0.17	7.5										
Ferry Terminal	11/03/15	0.5	0.19	7.7										
	11/10/15	0.3	0.16	7.5										
	11/18/15	0.7	0.15	7.5										
	11/24/15	0.4	0.13	7.5										
Highway 19 PRV	11/03/15	0.9	0.71	7.4										
	11/10/15	0.8	0.15	7.5										
	11/17/15	0.8	0.13	7.5										
	11/24/15	0.9	0.15	7.6										
Average		0.6	0.24	7.6										
Minimum		0.1	0.11	7.4										
Maximum		0.9	0.72	8.2										
Chatham Avenue	12/01/15	0.7	0.10	7.9										
	12/08/15	0.6	0.15	7.9										
	12/15/15	0.5	0.16	7.9										
	12/22/15	0.6	0.13	7.8										
	12/29/15	0.6	0.25	7.7										
	12/01/15	0.8	0.15	7.6										
	12/08/15	0.8	0.10	8.0										
	12/15/15	0.8	0.14	7.6										
	12/22/15	0.8	0.15	7.7										
	12/29/15	0.7	0.24	7.4										
	Peel Street Lifestation	12/01/15	0.7	0.39	7.5									
12/08/15		0.7	0.21	7.9										
12/15/12		0.7	0.49	7.8										
12/22/15		0.7	0.16	7.5										
12/29/15		0.5	0.26	7.8										
12/01/15		0.8	0.18	7.7										
12/08/15		0.7	0.21	8.0										
12/15/15		0.8	0.13	7.8										
12/22/15		0.6	0.11	7.6										
12/29/15		0.7	0.16	7.8										
12/01/15		0.2	0.26	7.8										
Airport Wastewater Treatment Plant	12/08/15	0.3	0.49	8.2										
	12/15/15	0.2	0.21	8.0										
	12/22/15	0.4	0.29	7.8										
	12/29/15	0.2	0.30	7.7										
	12/01/15	0.8	0.18	7.5										
	12/08/15	0.6	0.12	7.8										
	12/15/15	0.7	0.22	7.6										
	12/22/15	0.7	0.14	7.6										
	12/29/15	0.8	0.19	7.5										
	12/01/15	0.7	0.22	7.6										
	12/08/15	0.6	0.20	7.8										
Public Works Yard	12/15/15	0.6	0.19	7.6										
	12/22/15	0.7	0.21	7.6										
	12/29/15	0.7	0.22	7.5										
	12/01/15	0.8	0.42	7.7										
	12/08/15	0.8	0.34	8.3										
	12/15/15	1.0	0.14	7.6										
	12/22/15	0.8	0.13	7.7										
	12/29/15	0.9	0.18	7.5										
	Average		0.6	0.21	7.7									
	Minimum		0.2	0.10	7.4									
	Maximum		0.8	0.49	8.2									

DISTRICT OF PORT HARDY

WATER SYSTEM ANNUAL REPORT 2015



January							February						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
01/13/15	Hospital	0.8	0.21	7.8	<1	<1	02/10/15	Hospital	0.9	0.26	7.6	<1	<1
01/12/15	Airport Washroom	0.5	0.27	7.6	<1	<1	02/17/15	Airport Washroom	0.2	0.20	7.8	<1	<1
01/12/15	Chatham Ave.	0.6	0.24	8.2	<1	<1	02/10/15	Chatham Ave.	0.7	0.20	8.0	<1	<1
01/13/15	Bear Cove Reservoir	0.8	0.24	7.6	<1	<1	02/04/15	Bear Cove Reservoir	0.7	0.18	7.5	<1	<1
01/13/15	Highway 19 PRV	1.0	0.21	7.7	<1	<1	02/04/15	Highway 19 PRV	1.0	0.21	7.6	<1	<1
01/20/15	Pioneer Inn	1.0	0.16	8.2	<1	<1	02/04/15	Pioneer Inn	0.9	0.13	7.5	<1	<1
01/12/15	Public Works Yard	0.9	0.19	7.7	<1	<1	02/24/15	Public Works Yard	0.8	0.13	7.9	<1	<1
01/20/15	Glen Lyon Restaurant	0.9	0.16	7.9	<1	<1	02/17/15	Glen Lyon Restaurant	0.8	0.14	7.8	<1	<1
01/20/15	Airport Inn	0.9	0.74	7.6	<1	<1	02/17/15	Airport Inn	0.8	0.12	7.8	<1	<1
01/13/15	Peel St Liftstation	0.8	0.33	7.6	<1	<1	02/24/15	Peel St Liftstation	1.1	0.14	7.5	<1	<1
01/12/15	B.C. Ferry	0.7	0.22	7.6	<1	<1	02/10/15	B.C. Ferry	0.6	0.13	7.6	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
01/20/15	Tsulquate River (Untreated)		0.71	6.5	88	1.0	02/04/15	Tsulquate River (Untreated)		0.62	6.6	110.6	<1
March							April						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
03/17/15	Hospital	1.0	0.15	7.6	<1	<1	04/21/15	Hospital	0.9	0.17	7.5	<1	<1
03/10/15	Airport Washroom	0.4	0.20	7.7	<1	<1	04/14/15	Airport Washroom	0.3	0.23	7.7	<1	<1
03/03/15	Chatham Ave.	0.6	0.20	7.7	<1	<1	04/07/15	Chatham Ave.	0.5	0.12	7.8	<1	<1
03/10/15	Bear Cove Reservoir	0.9	0.14	7.5	<1	<1	04/14/15	Bear Cove Reservoir	0.7	0.19	7.2	<1	<1
03/03/15	Highway 19 PRV	1.1	0.17	7.4	<1	<1	04/07/15	Highway 19 PRV	1.0	0.19	7.5	<1	<1
03/17/15	Pioneer Inn	1.0	0.13	7.6	<1	<1	04/07/15	Pioneer Inn	0.6	0.18	7.6	<1	<1
03/10/15	Public Works Yard	0.6	0.13	8.0	<1	<1	04/14/15	Public Works Yard	0.1	0.30	8.9	<1	<1
03/03/15	Glen Lyon Restaurant	0.8	0.12	7.4	<1	<1	04/22/15	Glen Lyon Restaurant	0.6	0.22	7.6	<1	<1
03/17/15	Airport Inn	0.9	0.12	7.6	<1	<1	04/21/15	Airport Inn	0.9	0.12	7.6	<1	<1
03/17/15	Peel St Liftstation	1.0	0.14	7.5	<1	<1	04/07/15	Peel St Liftstation	1.0	0.12	7.3	<1	<1
03/03/15	B.C. Ferry	0.7	0.13	7.4	<1	<1	04/21/15	B.C. Ferry	0.4	0.12	7.5	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
03/10/15	Tsulquate River (Untreated)		0.45	6.8	179.3	<1	04/21/15	Tsulquate River (Untreated)		0.64	6.6	410.6	<1
May							June						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
05/19/15	Hospital	0.7	0.20	7.7	<1	<1	06/16/15	Hospital	0.7	0.13	7.5	<1	<1
05/19/15	Airport Washroom	0.4	0.14	7.7	<1	<1	06/02/15	Airport Washroom	0.7	0.19	7.5	<1	<1
05/05/15	Chatham Ave.	0.4	0.14	8.2	<1	<1	06/02/15	Chatham Ave.	0.5	0.13	7.8	<1	<1
05/05/15	Bear Cove Reservoir	0.6	0.14	7.7	<1	<1	06/02/15	Bear Cove Reservoir	0.7	0.31	7.6	<1	<1
05/05/15	Highway 19 PRV	0.8	0.14	7.6	<1	<1	06/09/15	Highway 19 PRV	0.7	0.20	7.7	<1	<1
05/05/15	Pioneer Inn	0.8	0.17	7.6	<1	<1	06/02/15	Pioneer Inn	0.7	0.16	7.5	<1	<1
05/12/15	Public Works Yard	0.4	0.20	8.9	<1	<1	06/09/15	Public Works Yard	0.5	0.14	7.9	<1	<1
05/12/15	Glen Lyon Restaurant	0.6	0.18	8.0	<1	<1	06/16/15	Glen Lyon Restaurant	0.5	0.16	7.6	<1	<1
05/12/15	Airport Inn	0.5	0.17	7.9	<1	<1	06/09/15	Airport Inn	0.5	0.18	7.6	<1	<1
05/12/15	Peel St Liftstation	0.6	0.20	8.0	<1	<1	06/16/15	Peel St Liftstation	0.6	0.18	7.6	<1	<1
05/19/15	B.C. Ferry	0.3	0.19	7.6	<1	<1	06/09/15	B.C. Ferry	0.2	0.16	7.5	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	<i>E.Coli</i> CFU/100ml
05/19/15	Tsulquate River (Untreated)		0.32	7.0	410.6	2.0	06/16/15	Tsulquate River (Untreated)		0.20	7.1	461.1	1.0

DISTRICT OF PORT HARDY

WATER SYSTEM ANNUAL REPORT 2015



July							August						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
07/22/15	Hospital	0.6	0.17	7.8	<1	<1	08/18/15	Hospital	0.7	0.02	7.6	<1	<1
07/07/15	Airport Washroom	0.2	0.14	7.7	<1	<1	08/04/15	Airport Washroom	0.2	0.21	7.6	<1	<1
07/22/15	Chatham Ave.	0.4	0.13	7.8	<1	<1	08/18/15	Chatham Ave.	0.4	0.06	7.7	<1	<1
07/07/15	Bear Cove Reservoir	0.5	0.15	7.7	<1	<1	08/04/15	Bear Cove Reservoir	0.8	0.19	7.5	<1	<1
07/22/15	Highway 19 PRV	0.8	0.17	7.7	<1	<1	08/04/15	Highway 19 PRV	0.9	0.15	7.4	<1	<1
07/14/15	Pioneer Inn	0.7	0.13	7.5	<1	<1	08/18/15	Pioneer Inn	0.7	0.11	7.7	<1	<1
07/14/15	Public Works Yard	0.4	0.12	8.0	<1	<1	08/11/15	Public Works Yard	0.4	0.19	7.9	<1	<1
07/07/15	Glen Lyon Restaurant	0.6	0.12	7.6	<1	<1	08/11/15	Glen Lyon Restaurant	0.5	0.16	7.7	<1	<1
07/14/15	Airport Inn	0.5	0.19	7.6	<1	<1	08/18/15	Airport Inn	0.6	0.24	7.6	<1	<1
07/07/15	Peel St Liftstation	0.7	0.20	7.8	<1	<1	08/11/15	Peel St Liftstation	0.6	0.18	7.6	<1	<1
07/14/15	B.C. Ferry	0.5	0.14	7.5	<1	<1	08/11/15	B.C. Ferry	0.3	0.31	7.6	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
07/22/15	Tsulquate River (Untreated)		0.25	7.0	1413.6	28.8	08/04/15	Tsulquate River (Untreated)		0.27	7.1	1732.9	19.7
September							October						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
09/08/15	Hospital	0.6	0.24	7.5	<1	<1	10/13/15	Hospital	0.6	0.13	7.8	<1	<1
09/15/15	Airport Washroom	0.5	0.18	7.7	<1	<1	10/06/15	Airport Washroom	0.5	0.23	7.7	<1	<1
09/08/15	Chatham Ave.	0.4	0.12		<1	<1	10/20/15	Chatham Ave.	0.5	0.14	7.6	<1	<1
09/01/15	Bear Cove Reservoir	0.5	0.20	7.6	<1	<1	10/13/15	Bear Cove Reservoir	0.5	0.16	7.6	<1	<1
09/01/15	Highway 19 PRV	0.7	0.21		<1	<1	10/06/15	Highway 19 PRV	0.8	0.12	7.6	<1	<1
09/08/15	Pioneer Inn	0.6	0.14	7.4	<1	<1	10/20/15	Pioneer Inn	0.7	0.16	7.5	<1	<1
09/15/15	Public Works Yard	0.2	0.09	8.4	<1	<1	10/20/15	Public Works Yard	0.8	0.14	7.9	<1	<1
09/15/15	Glen Lyon Restaurant	0.7	0.16	7.6	<1	<1	10/13/15	Glen Lyon Restaurant	0.7	0.12	7.6	<1	<1
09/15/15	Airport Inn	0.6	0.20	7.6	<1	<1	10/20/15	Airport Inn	0.6	0.28	7.6	<1	<1
09/01/15	Peel St Liftstation	0.4	0.22	7.2	<1	<1	10/06/15	Peel St Liftstation	0.7	0.12	7.5	<1	<1
09/08/15	B.C. Ferry	0.2	0.14	7.5	<1	<1	10/06/15	B.C. Ferry	0.3	0.12	7.6	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
09/01/15	Tsulquate River (Untreated)		1.00	6.6	>2419.2	101.2	10/13/15	Tsulquate River (Untreated)		0.71	6.8	488.4	12.2
November							December						
Bacteriological Sampling							Bacteriological Sampling						
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
11/03/15	Hospital	0.7	0.15	7.5	<1	<1	12/15/15	Hospital	0.8	0.14	7.8	<1	<1
11/24/15	Airport Washroom	0.1	0.19	7.7	<1	<1	12/08/15	Airport Washroom	0.5	0.15	7.7	<1	<1
11/17/15	Chatham Ave.	0.4	0.12	7.9	<1	<1	12/08/15	Chatham Ave.	0.6	0.15	7.9	<1	<1
	Bear Cove Reservoir				<1	<1	12/01/15	Bear Cove Reservoir	0.8	0.18	7.5	<1	<1
11/17/15	Highway 19 PRV	0.8	0.13	7.5	<1	<1	12/01/15	Highway 19 PRV	0.8	0.42	7.7	<1	<1
11/24/15	Pioneer Inn	0.6	0.15	7.6	<1	<1	12/15/15	Pioneer Inn	0.7	0.19	7.6	<1	<1
11/17/15	Public Works Yard	0.3	0.14	8.2	<1	<1	12/08/15	Public Works Yard	0.7	0.21	8.0	<1	<1
11/03/15	Glen Lyon Restaurant	0.7	0.12	7.6	<1	<1	12/15/15	Glen Lyon Restaurant	0.7	0.14	7.6	<1	<1
11/03/15	Airport Inn	0.6	0.30	7.7	<1	<1	12/15/15	Airport Inn	0.7	0.31	7.5	<1	<1
11/17/15	Peel St Liftstation	0.7	0.13	7.5	<1	<1	12/01/15	Peel St Liftstation	0.8	0.15	7.6	<1	<1
11/03/15	B.C. Ferry	0.5	0.19	7.7	<1	<1	12/08/15	B.C. Ferry	0.6	0.20	7.8	<1	<1
Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml	Sample Date	Sample Location	Free Chlorine (mg/L)	Turbidity (NTU)	pH	Total Coliform CFU/100ml	E.Coli CFU/100ml
11/25/15	Tsulquate River (Untreated)		0.50	6.7	214.3	<1	12/01/15	Tsulquate River (Untreated)		0.31	6.9	275.5	2.0

DISTRICT OF PORT HARDY WATER SYSTEM ANNUAL REPORT 2015



Exova
#104, 19575-55 A.Ave.
Surrey, British Columbia
V3B 8P8, Canada

T: +1 (604) 514-3322
F: +1 (604) 514-3323
E: Surrey@exova.com
W: www.exova.com

Page 1 of 2



Analytical Report

Bill To: District of Port Hardy	Project:	Lot ID: 1048729
Report To: District of Port Hardy	ID:	Control Number:
Water & Wastewater Division	Name:	Date Received: Jan 14, 2015
8900 Park Drive	Location:	Date Reported: Jan 22, 2015
Port Hardy, BC, Canada	LSD:	Report Number: 1981845
VON 2P0	P.O.:	
Attn: Joe Jewell	Acct code:	
Sampled By:		
Company:		

Analyte	Units	Reference Number	1048729-1	1048729-2	Nominal Detection Limit
		Sample Date	Jan 13, 2015	Jan 13, 2015	
		Sample Time	NA	NA	
		Sample Location	Reservoir	Chatham Ave.	
	Matrix	Water	Water	Water	
Trihalomethanes Screen - Water					
Chloroform	mg/L	Results	0.021	0.035	0.001
Bromodichloromethane	mg/L	Results	<0.001	0.001	0.001
Dibromochloromethane	mg/L	Results	<0.001	<0.001	0.001
Bromoform	mg/L	Results	<0.001	<0.001	0.001
Total Trihalomethanes	mg/L	Results	0.021	0.036	0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate	%	99	99	86-118
Toluene-d8	EPA Surrogate	%	98	99	85-115
Bromofluorobenzene	EPA Surrogate	%	100	98	86-115
Haloacetic Acids - Water					
Monochloroacetic Acid	ug/L	Results	<2.0	<2.0	2
Monobromoacetic Acid	ug/L	Results	<2.0	<2.0	2
Dichloroacetic Acid	ug/L	Results	8.0	14.2	2
Bromochloroacetic Acid	ug/L	Results	<2.0	<2.0	2
Dibromoacetic Acid	ug/L	Results	<2.0	<2.0	2
Trichloroacetic Acid	ug/L	Results	10.8	17.5	2
Total Haloacetic Acids (HAA6)	ug/L	Results	18.8	31.7	2


 Approved by: Mathieu Simoneau
 Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
 Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Terms and Conditions: www.exova.com/about/terms-and-conditions

DISTRICT OF PORT HARDY

WATER SYSTEM ANNUAL REPORT 2015



Exova
 #104, 19575-55 A Ave.
 Surrey, British Columbia
 V3S 8P8, Canada

T: +1 (604) 514-3322
 F: +1 (604) 514-3323
 E: Surrey@exova.com
 W: www.exova.com

Page 1 of 3



Analytical Report

Bill To: District of Port Hardy
 Report To: District of Port Hardy
 Water & Wastewater Division
 8900 Park Drive
 Port Hardy, BC, Canada
 V0N 2P0
 Attn: Joe Jewell
 Sampled By: R. Le Fort
 Company: DPH

Project:
 ID:
 Name:
 Location:
 LSD:
 P.O.:
 Acct code:

Lot ID: **1063349**
 Control Number:
 Date Received: Apr 9, 2015
 Date Reported: Apr 16, 2015
 Report Number: 2001487

Reference Number	1063349-1	1063349-2			
Sample Date	Apr 08, 2015	Apr 08, 2015	Sample Time	09:15	10:00
Sample Location	Port Hardy	Port Hardy	Sample Description	Port Hardy / Port Hardy Reservoir Water	Port Hardy / Chatham Ave. Water
Matrix			Analyte		
Units	Results	Results	Results	Nominal Detection Limit	
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.023	0.044		0.001
Bromodichloromethane	mg/L	0.002	0.003		0.001
Dibromochloromethane	mg/L	<0.001	<0.001		0.001
Bromoform	mg/L	<0.001	<0.001		0.001
Total Trihalomethanes	mg/L	0.025	0.047		0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate	%	90	93	86-118
Toluene-d8	EPA Surrogate	%	98	99	85-115
Bromofluorobenzene	EPA Surrogate	%	95	95	86-115
Haloacetic Acids - Water					
Monochloroacetic Acid	ug/L	<2.0	<2.0		2
Monobromoacetic Acid	ug/L	<2.0	<2.0		2
Dichloroacetic Acid	ug/L	9.9	17.0		2
Bromochloroacetic Acid	ug/L	<2.0	<2.0		2
Dibromoacetic Acid	ug/L	<2.0	<2.0		2
Trichloroacetic Acid	ug/L	13.7	22.0		2
Total Haloacetic Acids (HAA6)	ug/L	23.6	39.0		2


 Approved by:
 Mathieu Simoneau
 Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
 Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Terms and Conditions: www.exova.com/about/terms-and-conditions

**DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015**



Exova
#104, 19575-55 A.Ave.
Surrey, British Columbia
V3S 8P6, Canada
T: +1 (604) 514-3322
F: +1 (604) 514-3323
E: Surrey@exova.com
W: www.exova.com

Page 1 of 3



Analytical Report

Bill To: District of Port Hardy
Report To: District of Port Hardy
Water & Wastewater Division
8900 Park Drive
Port Hardy, BC, Canada
V0N 2P0
Attn: Joe Jewell
Sampled By:
Company: DPH

Project:
ID:
Name:
Location:
LSD:
P.O.:
Acct code:

Lot ID: 1082089
Control Number:
Date Received: Jul 15, 2015
Date Reported: Jul 23, 2015
Report Number: 2026561

	Reference Number	1082089-1	1082089-2		
	Sample Date	Jul 14, 2015	Jul 14, 2015		
	Sample Time	NA	NA		
	Sample Location	Port Hardy	Port Hardy		
	Sample Description	Port Hardy / WTP Reservoir Water	Port Hardy / Chatham Ave. Water		
	Matrix	Water	Water		
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.032	0.049		0.001
Bromodichloromethane	mg/L	0.002	0.003		0.001
Dibromochloromethane	mg/L	<0.001	<0.001		0.001
Bromoform	mg/L	<0.001	<0.001		0.001
Total Trihalomethanes	mg/L	0.034	0.052		0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate %	111	107		86-118
Toluene-d8	EPA Surrogate %	105	106		85-115
Bromofluorobenzene	EPA Surrogate %	89	89		86-115
Haloacetic Acids - Water					
Monochloroacetic Acid	ug/L	<2.0	<2.0		2
Monobromoacetic Acid	ug/L	<2.0	<2.0		2
Dichloroacetic Acid	ug/L	11.1	17.0		2
Bromochloroacetic Acid	ug/L	<2.0	<2.0		2
Dibromoacetic Acid	ug/L	<2.0	<2.0		2
Trichloroacetic Acid	ug/L	15.7	24.3		2
Total Haloacetic Acids (HAA6)	ug/L	26.8	41.3		2

Approved by:

Carol Nam, Dipl. T.
Quality Officer

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.
Terms and Conditions: www.exova.com/about/terms-and-conditions

DISTRICT OF PORT HARDY
WATER SYSTEM ANNUAL REPORT 2015



Exova
 #104, 19575-55 A Ave.
 Surrey, British Columbia
 V3S 8P8, Canada
 T: +1 (604) 514-3322
 F: +1 (604) 514-3323
 E: Surrey@exova.com
 W: www.exova.com

Page 1 of 3



Analytical Report

Bill To: District of Port Hardy	Project:	Lot ID: 1100184
Report To: District of Port Hardy	ID:	Control Number:
Water & Wastewater Division	Name:	Date Received: Oct 15, 2015
8900 Park Drive	Location:	Date Reported: Oct 23, 2015
Port Hardy, BC, Canada	LSD:	Report Number: 2050852
VON 2P0	P.O.:	
Attn: Joe Jewell	Acct code:	
Sampled By:		
Company: DPH		

Reference Number	1100184-1	1100184-2			
Sample Date	Oct 14, 2015	Oct 14, 2015			
Sample Time	09:00	09:45			
Sample Location	Port Hardy	Port Hardy			
Sample Description	Port Hardy / Port Hardy Reservoir Water	Port Hardy / Chatham Ave. Water			
Matrix	Water	Water			
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Trihalomethanes Screen - Water					
Chloroform	mg/L	0.039	0.059		0.001
Bromodichloromethane	mg/L	0.002	0.003		0.001
Dibromochloromethane	mg/L	<0.001	<0.001		0.001
Bromoform	mg/L	<0.001	<0.001		0.001
Total Trihalomethanes	mg/L	0.041	0.062		0.001
Trihalomethanes - Surrogate Recovery					
Dibromofluoromethane	EPA Surrogate %	105	108		88-118
Toluene-d8	EPA Surrogate %	99	99		85-115
Bromofluorobenzene	EPA Surrogate %	95	94		88-115
Haloacetic Acids - Water					
Monochloroacetic Acid	ug/L	<2.0	<2.0		2
Monobromoacetic Acid	ug/L	<2.0	<2.0		2
Dichloroacetic Acid	ug/L	13.3	16.8		2
Bromochloroacetic Acid	ug/L	<2.0	<2.0		2
Dibromoacetic Acid	ug/L	<2.0	<2.0		2
Trichloroacetic Acid	ug/L	17.5	20.0		2
Total Haloacetic Acids (HAA6)	ug/L	30.8	38.8		2


 Approved by: Mathieu Simoneau
 Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
 Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.
 Terms and Conditions: www.exova.com/about/terms-and-conditions