



# District of Port Hardy

7360 Columbia Street ♦ PO Box 68  
Port Hardy BC V0N 2P0 Canada  
Telephone: (250) 949-6665 ♦ Fax (250) 949-7433  
Email: general@porthardy.ca ♦ www.porthardy.ca



## Request for Quotations

Reference No. 1220-20-532-2019

### SUPPLY AND DELIVERY OF SELF-CONTAINED BREATHING APPARATUS (SCBA), CYLINDERS, AND ACCESSORIES

Port Hardy Fire Rescue has currently procured a 9.0 SCFM Bauer vertical breathing air compressor rated for 6100 PSI. The Fire Department is looking to purchase 22 SCBA with 4500 PSI cylinders and accessories.

The District of Port Hardy on behalf of Port Hardy Fire Rescue is requesting submissions for the supply, and delivery to the District of Port Hardy Fire Hall #1 8890 Central Avenue Port Hardy, BC, for: **22 SCBA with 4500 PSI cylinders and accessories.**

**Supply and deliver (two options for quotations):**

**Option #1 MSA:**

Item	Qty
G-1 pack with rechargeable battery	22
G-1 cylinder 45 minute 4500 PSI LP carbon fibre	44
G-1 facepiece with 4 point harness and neck strap, sizes TBD	22
Quick connect coupler on SCBA	22
Quick connect valve on cylinders	44
Voice amplifier	22
Extend Aire II	22
Quick Connect couplers to be added to SCBA fill station whips	4

**Option #2 SCOTT:**

Item	Qty
X3 Pro 4.5 pack with QD quick disconnect	22
4.5 4500 PSI 45 minute 4500 PSI carbon fibre with quick connect	44
AV 3000 Mask HT with RT bracket, sizes TBD	22
Quick connect coupler on SCBA	22
Quick connect valve on cylinders	44
Epic 3 Voice amplifier	22
EBBS Emergency Breathing Support System	22
Quick Connect couplers to be added to SCBA fill station whips	4



# District of Port Hardy

7360 Columbia Street ♦ PO Box 68  
Port Hardy BC V0N 2P0 Canada  
Telephone: (250) 949-6665 ♦ Fax (250) 949-7433  
Email: [general@porthardy.ca](mailto:general@porthardy.ca) ♦ [www.porthardy.ca](http://www.porthardy.ca)



This is a Request for Quotations only. By requesting quotations, the District of Port Hardy does not intend to enter into, and shall not be considered to have entered into, contractual relations upon the submission of a quotation by any person and no "Contract A" shall be formed between the District of Port Hardy and any supplier upon the submission of a quotation. Without limiting the foregoing, the District shall not be obligated in any manner whatsoever to any supplier until a written agreement for the performance of the work herein contemplated has been duly executed.

Quotations will be evaluated based on price, warranty, serviceability, product performance, cost of ownership and other factors, as determined by the District of Port Hardy's purchasing policy.

Quotations must be submitted by email to [general@porthardy.ca](mailto:general@porthardy.ca) with the subject: 'Request for Quotations Reference No. 1220-20-532-2019' or in a **sealed** envelope, clearly marked with suppliers name and above project name and description and received by **2:00 p.m. (local time) Friday August 16, 2019.**

District of Port Hardy, Municipal Hall  
7360 Columbia Street  
PO Box 68  
Port Hardy, BC V0N 2P0

**Acceptance:** Quotations must remain valid for sixty (60) days after the closing date.

**Errors:** Quotations as received shall be considered final and no quotation shall be altered, amended or withdrawn after the specified closing date.

**Completion/Delivery/Cancellation:** The specified completion or delivery dates should be carefully considered before bidders submit a quote. Failure to meet promised completion/delivery dates may result in cancellation of any subsequent contract.

**Taxes:** Quotations must show appropriate taxes separately.

**Awards:** The District reserves the right to award the order in part or in full, on the basis of quotations received, unless otherwise specified by the District.

**Submission of Bids:** The District shall not be bound and the Bidder agrees not to rely upon any written or verbal statements or representations of any other persons, whether employed by the District or not, in the preparation and submission of their bid.

**Quantities:** The District reserves the right to increase or decrease quantities related herein to meet operational or budget requirements.



# District of Port Hardy

7360 Columbia Street ♦ PO Box 68  
Port Hardy BC V0N 2P0 Canada  
Telephone: (250) 949-6665 ♦ Fax (250) 949-7433  
Email: [general@porthardy.ca](mailto:general@porthardy.ca) ♦ [www.porthardy.ca](http://www.porthardy.ca)



The Proponent shall provide written documentation of all Warranties

The Proponent will represent and warrant to the District that the Self Contained Breathing Apparatus:

1. Meet minimum specifications;
2. Are free from any defects in design, materials, and workmanship, or affecting its operation; and
3. The Proponent will honor all and any warranties offered in writing on the Self Contained Breathing Apparatus.

The Proponent will state the Manufacturer-Authorized Mobile Service Technician that will provide service to Port Hardy Fire Rescue.

The Proponent will designate in writing the names and addresses of an agent or agents who are authorized to accept notice from the District and who have the authority to accept the Self Contained Breathing Apparatus for repair or replacement on behalf of the Proponent and the agents shall be available to the District at all reasonable times.

The Proponent will ensure that the Self Contained Breathing Apparatus be changed or replaced in accordance with any Manufacturer's Recall Programs as soon as possible upon notification of recalls.

All Self Contained Breathing Apparatus:

1. Shall meet all requirements of NFPA 1981: Standard on Open-Circuit Self Contained Breathing Apparatus (SCBA) for Emergency Service, 2018 Edition.
2. Shall be compliant to NFPA 1982, 2018 edition, Standard on Personal Alert Safety Systems.
3. Shall be compliant with all requirements of Worksafe BC.
4. Shall have a manufacturing date no more than six (6) months prior to the delivery date.

For more information please contact:

Brent Borg, Fire Chief  
[firechief@porthardy.ca](mailto:firechief@porthardy.ca)  
District of Port Hardy  
250-230-0341

**Location: Northern Vancouver Island**