

DISTRICT OF PORT HARDY

ADDENDUM NO. 1

RFP Title: Quatse Bridge Replacement

RFP Number:1220-20-619-2026

Issue Date: March 26, 2026

Addendum Date: April 1, 2026

CLARIFICATIONS & RESPONSES

Q1. As-built drawings of the bridge if they exist.

Response:

There are no as-builts.

Q2. Any picture of the bridge, including the attachment of existing municipal water and sanitary sewer mains.

Response:

See the attachments at the end of the document.

Q3. Accurate location or directions to the bridge location.

Response:

50.697646, -127.482980 / Coal Harbour Rd, Port Hardy, BC V0N 2P0

Q4. Span and width of existing bridge.

Response:

Span is roughly 80ft and width of existing bridge is 15ft.

Q5. What are the bridge standards the new bridge is to meet. What ratings is the new bridge to meet.

Response:

The bridge is to safely hold pedestrian traffic, support a water and sewer forcemain, quads, and mini electric maintenance trucks.

Q6. Size of water main size of sewer main.

Response:

Water 300 mm & Sewer is 150 mm

Q7. Completion date for bridge

Response:

Aiming for the fish window of August 2026.

Q8. Has port hardy reached out to DFO about this project.

Response:

No.

Q9. The existing bridge material (Timber, Steel, or Aluminum):

Response:

Mostly Timber to our knowledge.

Q10. Budget for this project.

Response:

\$256,000.00

Q11. Preference of type of bridge.

Response:

Aluminum, low-maintenance bridge.

Q12. The existing bridge's estimated weight:

Response:

Unknown.

Q13. Is there a minimum width requirement for the new bridge?

Response:

No

Q14. Can the RFP be extended one week?

Response:

Yes, extension to the RFP 2:00 pm April 16, 2026

ATTACHMENTS

Attachment 1.



Attachment 2.



Attachment 3.



Attachment 4 Sewer Pipe.



Attachment 5 Water Pipe.



Attachment 6.



Attachment 7.



Attachment 8.



Attachment 9.



Attachment 10.



END OF ADDENDUM NO. 1